



WHERE FIRE SERVICES HAVE HOSE REELS IN AREAS SUBJECT TO POTENTIAL INTERCONNECTION WITH CONTAMINANTS, THE TYPE OF BACKFLOW PREVENTION DEVICE INSTALLED AT THE WATER METER MUST BE RELEVANT TO THE HAZARD RATING OF THE PROPERTY.

PROPERTY OWNER'S RESPONSIBILITY FROM WATER MAIN EXCEPT FOR WATER METER

SPECIFIC CONSENT REQUIRED FROM RELEVANT FIRE AUTHORITY

FOR THE USE OF INLINE WATER METERS REFER TO METERING GUIDELINES, CLAUSE 10.4

SCHEDULE OF ITEMS			
ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17	9	BACKFLOW PREVENTION DEVICE AND ASSOCIATED VALVING TO BE RELEVANT TO HAZARD RATING
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE		
4	DIRT BOX WATER CORPORATION SUPPLIED	METERS 50mm AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK	
5	SPACER 5 x PIPE DIAMETER		
6	APPROVED WATER CORPORATION SUPPLIED WATER METER		
7	SPACER 3 x PIPE DIAMETER	SEE GENERAL NOTES FOR FURTHER INFORMATION	
8	TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm		

STANDARD LEGEND		
⊗	V	Valve
○	M	Meter
□	D.B.	Dirt Box
—	S.P.	Straight Piece
⊥	T.F.	Testing Ferrule
▭	L.S.	Line Strainer
∩	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
∩	S.C.V.T	Single Check Valve Testable
∩	S.C.D.A.T.	Single Check Detector Assembly Testable