



ANNUAL DRINKING WATER QUALITY REPORT 2020-21

South Gippsland Region Water Corporation



START SAFE 
WORK SAFE 
HOME SAFE 




Table of Contents

| | |
|---|----|
| 1. Introduction - from the Managing Director | 1 |
| Characterisation of the System..... | 2 |
| 2. Water Treatment and Quality Management Systems | 6 |
| Water treatment overview | 6 |
| Changes in water treatment and supply conditions | 6 |
| Water Treatment Issues | 11 |
| Quality Management Systems and Continual Improvement | 12 |
| 3. Emergency, Incident, and Event Management | 14 |
| Incidents reported under the Safe Drinking Water Act..... | 14 |
| Other potential issues | 16 |
| 4. Drinking Water Quality Standards | 17 |
| Analysis Results – Schedule 2 parameters | 18 |
| Analysis Results - Other water quality standards (algal toxin, pathogen, chemical or substance that may pose a risk to human health)..... | 22 |
| Aesthetics | 39 |
| Analysis of results..... | 47 |
| 5. Complaints relating to water quality for 2020-21 | 49 |
| 6. Findings of the most recent risk management plan audit | 54 |
| 7. Regulated water | 55 |
| 8. Appendices | 56 |
| Appendix 1: South Gippsland Water’s Drinking Water Quality Policy | 56 |
| Appendix 2: Safe Drinking Water Act audit certificate | 56 |
| Appendix 3: Amendment to audit certificate | 57 |
| Appendix 4: Progress summary for 2020 risk management plan audit | 58 |
| Appendix 5: Progress summary for 2018 risk management plan audit | 59 |
| Glossary of acronyms and terms used in report..... | 63 |
| Glossary of water treatment agents and processes..... | 64 |

1. Introduction - from the Managing Director

I am pleased to present South Gippsland Water's annual drinking water quality report for the year ending 30 June 2021. In accordance with requirements of the *Safe Drinking Water Act 2003* ("the Act"), this report summarises our performance against water quality standards, provides an overview of management practices, and describes how we respond to water quality challenges as they arise.

*"Committed to high-quality drinking water"*¹

As part of South Gippsland Water's commitment to quality, we maintain a drinking water management system based on Hazard Analysis and Critical Control Point (HACCP) principles and the Australian Drinking Water Guidelines². The system incorporates a catchment-to-tap monitoring program to ensure drinking water meets legislative requirements of the Act and associated Safe Drinking Water Regulations 2015 ("the Regulations"). Information on water treatment, quality management systems, and operational improvements can be found in part 2 of this report.

For the 2020/21 fiscal year, South Gippsland Water achieved 100% compliance with the prescribed standards of the Regulations for *Escherichia coli*, trihalomethanes, and turbidity. A summary of results from our comprehensive monitoring program is provided in part 4. Also worth noting is the outcome of a drinking water risk management plan audit, conducted in August 2020. As further testament to our commitment to providing high quality drinking water, South Gippsland Water was found to be compliant in all auditable elements. Details are provided in Part 6.

Customer satisfaction is especially important to us at South Gippsland Water, and we strive to meet expectations in terms of supplying water that is both safe and pleasant to drink. In doing so we take pride in giving prompt and helpful service in response to water quality concerns. Information on customer complaints is provided in Part 5.

The year has provided challenges related to the on-going COVID-19 pandemic. We have had to continue to adapt our ways of working and postpone some non-critical activities. Despite this, several major improvement projects have been completed in 2020/21. These include upgrades of taste and odour control systems at Lance Creek and Foster water treatment plants, and renewal of storage basin linings and covers at Fish Creek and Toora.

We are proud of all our successes in 2020/21, most notably delivering on our promise to provide clean, safe drinking water to the South Gippsland region. I trust you will find this report informative. For additional information on anything presented within, I invite you to contact us by phoning 1300 851 636 or emailing sgwater@sgwater.com.au



Philippe du Plessis
Managing Director

¹ South Gippsland Water Drinking Water Quality Policy

² National Health and Medical Research Council Australian Drinking Water Guidelines 2011

Characterisation of the System

Source water systems and catchment management

As part of the catchment-to-tap approach to providing safe drinking water, South Gippsland Water monitors for hazards in all water supply catchments. This approach is underpinned by the preventative and multiple barrier principles described in the *Australian Drinking Water Guidelines 2011* (ADWG). The ADWG states that “prevention of contamination provides greater surety than removal of contaminants by treatments, so the most effective barrier is protection of source waters to the maximum degree practicable.”

South Gippsland Water is reliant on “open catchments” for all source water. An open catchment is one in which part or all the rainfall catchment area is in private ownership and land usage and public access is largely unrestricted. This presents a challenge in that complete protection of source water from farm and other run-off is not possible. Crucial to our role as a water supplier is improving our catchments as much as is achievable both within our own control and by engagement with other stakeholders.

Where hazards cannot be prevented, they are managed with robust and reliable barriers. Examples of these measures are documented in our Water Supply Catchment Monitoring Assessment and Improvement Program which is integrated into the Water Safety Plan and the Drinking Water Quality Management System. The program involves coordination of activities, including catchment surveillance, river health monitoring, land use planning assessment, and Source Water and Health-Based Target reporting. The Corporation also undertakes various catchment improvement works, including tree plantings and weed control, as well as promoting the importance of source water protection to the community via stakeholder engagement programs.

For the 2020-21 fiscal year, specifically, South Gippsland Water (SGW) catchment management activities included:

- Full time weed control at all SGW sites including land surrounding source water reservoirs.
- A continued program of tree plantings at Foster Dam to create additional protection to the source water.
- Investigation into development of improved management strategies in the Lance Creek Water Supply Catchment, including stakeholder engagement with dairy farmers in the catchment.
- Monthly communications with South Gippsland Shire Council on wastewater inspections and programs within the Tarwin River Water Supply Catchment Area.
- Continual engagement with the West Gippsland Catchment Management Authority (WGCMA) on projects including the Corner Inlet Management Program, Powlett River Management Program, Regional Catchment Strategy Update, and communications regarding works, projects and strategies undertaken by SGW within the WGCMA management area.
- Communications and support of strategies and projects undertaken by Port Phillip Catchment Management Authority in the SGW region.
- Support of South Gippsland Landcare projects (SGLC). SGW provided support for a \$23,000 grant for SGLC to undergo tree planting and fencing works in the Tarwin River Catchment.
- Continual business as usual assessment of Section 55 Planning Applications for suitability in the SGW drinking water supply catchment areas. There is much pressure on the drinking water catchments for

the increase of dwellings in all SGW catchments. SGW being a referral authority work diligently to assess these planning applications considering risk to the water supply catchment areas.

South Gippsland Water supply system

The service area of South Gippsland Water (SGW) covers approximately 4,000 square kilometres of the South Gippsland region, from Wonthaggi in the west to Yarram in the east; refer to Figure 1 – Map of South Gippsland Water water supply area and systems. The total water supply operation for 2020-21 comprised:

- 19 Water sampling localities
- 1,234 square kilometres of total catchment area
- 9 reservoirs and 4 raw water storage basins or tanks
- 8 water treatment plants and water supply systems
- 26 treated water distribution storages
- 18 water pumps
- 750 kilometres of water mains
- 22,405 connected properties supplying a population of approximately 37,000 permanent residents
- 4,631 megalitres (million litres) of metered water supplied to customers
- A connection pipeline from the Melbourne water grid to the Lance Creek water treatment plant



Photo: Picturesque South Gippsland hills and sky as seen from Lance Creek Water Treatment Plant

Table 1: South Gippsland Water water sampling localities and supply sources

| Localities supplied | Population serviced ³ | Principal raw water supply sources | Supplementary source water supply sources | Raw water storage | Water treatment plant |
|--|--|------------------------------------|--|---|-----------------------|
| Alberton Yarram | 560 2,480 | Tarra River | Gippsland Basin groundwater aquifer (via bore, Devon North) | Devon North Raw Water Basin | Devon North |
| Dumbalk | 410 | Tarwin River (east branch) | | Dumbalk Raw Water Tank | Dumbalk |
| Fish Creek | 830 | Battery Creek | | Battery Creek Reservoir | Fish Creek |
| Foster | 1,840 | Deep Creek | | Deep Creek Reservoir Foster Dam Foster Raw Water Basin | Foster |
| Cape Paterson Inverloch Lance Creek Wonthaggi Korumburra Loch Nyora Poowong | 890 5,390 100 8,680 4,470 640 1,530 640 | Lance Creek | Potable water also received from Cardinia Reservoir and Victorian Desalination Plant | Lance Creek Reservoir | Lance Creek |
| Koonwarra Leongatha | 400 5,650 | Ruby Creek | | No. 1 Reservoir No. 2 Reservoir No. 3 Reservoir (Hyland) No. 4 Reservoir (Western) | Leongatha |
| Meeniyen | 770 | Tarwin River | | Meeniyen Raw Water Basin | Meeniyen |
| Port Franklin Port Welshpool Toora | 140 540 780 | Agnes River | | Cooks Dam | Toora |

³ Population Served based on ABS 2017 Census data. The ABS method of calculation of population is based on State Suburbs (SSC) and may not always reflect the exact sewer/water district.




Figure 1: South Gippsland Water water supply area and systems

2. Water Treatment and Quality Management Systems

Water treatment overview

Conventional water treatment is a process whereby water is purified to a level suitable for human consumption. It generally begins with raw source water being allowed to settle in a reservoir so that natural sedimentation of large particulate matter can occur. The next step involves oxidation and precipitation of dissolved substances using aeration devices. Chemical agents are added as water flows through pipes from reservoir to the water treatment plant (WTP). The agents cause small particles to clump together into large insoluble masses known as floc in the processes of coagulation and flocculation. The floc formed is separated from water via gravitational settling or flotation. Filtration of the clarified water further reduces the load of small particles, microorganisms, and other contaminants. The final step in the process is disinfection. This commonly involves the addition of chlorine-based disinfectants, but other chemical agents or ultra-violet light may also be used to ensure water supplied to customers is free of harmful microorganisms.

A summary of the processes by which the drinking water supplied by South Gippsland Water (SGW) is treated and disinfected is provided in Table 2 and Table 3.



Photo: Aerial view of Lance Creek Water Treatment Plant and Reservoir

Changes in water treatment and supply conditions

The means of disinfection for the Yarram-Alberton water supply was changed to chlorination in November 2020. The water supply had previously been disinfected by addition of both chlorine and ammonia to form monochloramine (also referred to as “chloramine”). This compound is commonly used for long supply systems due to its stability and persistence to the ends of the system, as well as its ability to penetrate

biofilms. Another important benefit of monochloramine disinfection is that it does not contribute to formation of trihalomethanes and other potentially harmful chlorination by-products.

A disadvantage of monochloramine is that the disinfection process is slow compared to that of chlorine, which is a more powerful oxidant. This can become a risk during periods of peak water usage if there is inadequate contact time between the treated water and the monochloramine before the water enters the customer supply. When used as a primary disinfectant, a high dosage of monochloramine must be applied to compensate for this slow disinfection process.

As the chemical characteristics (specifically, the low levels of natural organic matter or “NOM”) of the Tarra River source are not conducive to high-level trihalomethane formation with use of chlorine, it was deemed appropriate that a change to chlorination be made. Following extensive preparation, a trial (with a view to continuation on a permanent basis) began on the 9th of November 2020.

The trial ran over the warm summer-autumn period, which is associated with maximum potential trihalomethane formation. Weekly monitoring of the water supply confirmed low trihalomethane risk, with results all being well under the regulatory health limit of 0.25 mg/L. The maximum result of 0.11 mg/L was recorded for Alberton at the end of December 2020. As higher temperatures are also associated with maximum chlorine decay, the trial allowed for optimisation of dosage to ensure persistence of residual chlorine to the ends of the supply system.

Customers were notified in advance of the change via notices, email, and social media. In all, there were only four customer complaints related to the change. Unidirectional mains flushing was carried out to hasten the replacement of chloraminated water with chlorinated water in the supply system. This was to mitigate potential taste and odour issues associated with mixing the two types of water and to remove any biofilms that may have sloughed off as result of the differing disinfection action of chlorine. An added benefit of the change to chlorine and related flushing program was this cleaning of the supply of system; it is a task that must be carried out periodically on most water supply systems to remove accumulated sediments and biofilms on the inner surfaces of pipes.



Photos: South Gippsland Water staff

Table 2: List of processes and chemicals used to treat and disinfect water supplied by SGW^A

| Water Treatment Plant (WTP) | Localities supplied | Treatment process | Treatment frequency | Added substances |
|-----------------------------|---|---|--|---|
| Devon North | Alberton Yarram | Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Dissolved air flotation clarification Filtration by granular medium Primary chloramination disinfection ⁵ Primary chlorination disinfection Dewatering of wastewater | As required As required Regular Regular Regular Regular Regular | Sodium carbonate Potassium permanganate Aluminium sulphate/chlorohydrate - - Sodium hypochlorite and ammonia Sodium hypochlorite - |
| Dumbalk | Dumbalk | Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Sedimentation clarification Filtration by granular medium Ultraviolet (UV) disinfection Primary chlorination disinfection Secondary chlorination disinfection Removal of volatile organics by aeration Dewatering of wastewater | Regular As required Regular Regular Regular Regular Regular Regular Regular | Sodium carbonate Potassium permanganate Aluminium chlorohydrate - - - Sodium hypochlorite Sodium hypochlorite - Anionic polyacrylamide |
| Fish Creek | Fish Creek | Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Sedimentation clarification Filtration by granular medium Post-treatment pH correction Primary chlorination disinfection Removal of volatile organics by aeration Secondary chlorination disinfection Dewatering of wastewater | Regular As required Regular Regular Regular Regular Regular Regular Regular | Sodium carbonate Potassium permanganate Aluminium sulphate - Anionic polyacrylamide Sodium carbonate Sodium hypochlorite - Sodium hypochlorite - |
| Foster | Foster | Taste and odour control Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Sedimentation clarification Filtration by granular medium Post-treatment pH correction Primary chlorination disinfection Secondary chlorination disinfection Dewatering of wastewater | As required Regular As required Regular Regular Regular Regular Regular Regular | Powdered activated carbon Sodium carbonate Potassium permanganate Aluminium sulphate/chlorohydrate - - Sodium carbonate Chlorine (gas) Sodium hypochlorite - |
| Lance Creek | Cape Paterson Inverloch Lance Creek Wonthaggi Korumburra Poowong Loch Nyora | Taste and odour control Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Dissolved air flotation clarification Filtration by granular medium Post-treatment pH correction Fluoridation Primary chlorination disinfection Secondary chloramination disinfection Dewatering of wastewater | As required As required As required Regular Regular Regular Regular Regular Regular Regular | Powdered activated carbon Sodium hydroxide / hydrochloric acid Potassium permanganate Aluminium sulphate/chlorohydrate - - Sodium hydroxide Hexafluorosilicic acid Chlorine (gas) Chlorine (gas) and ammonia Anionic polyacrylamide |

Table 2 continues over page

⁴ Refer to Glossary at end of report for further information

⁵ Disinfection was changed from chloramination to chlorination in November 2020

Table 2 (continued): List of processes and chemicals used to treat and disinfect water supplied by SGW

| Water Treatment Plant (WTP) | Localities supplied | Treatment process | Treatment frequency | Added substances |
|-----------------------------|---|---|--|---|
| Leongatha | Koonwarra Leongatha | Taste and odour control Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Sedimentation clarification Filtration by granular medium Post-treatment pH correction Primary chlorination disinfection Secondary chlorination disinfection Dewatering of wastewater | As required Regular As required Regular Regular Regular Regular Regular Regular Regular | Powdered activated carbon Sodium hydroxide Potassium permanganate Aluminium sulphate - Sodium hydroxide Chlorine (gas) Chlorine (gas) - |
| Meenyan | Meenyan | Manganese oxidation Coagulation and flocculation Sedimentation clarification Filtration by granular medium Chlorination disinfection Ultraviolet (UV) disinfection Removal of volatile organics by aeration Dewatering of wastewater | As required Regular Regular Regular Regular Regular Regular Regular | Sodium hypochlorite Aluminium chlorohydrate Anionic polyacrylamide - Sodium hypochlorite - - Anionic polyacrylamide |
| Toora | Port Franklin Port Welshpool Toora | Taste and odour control Pre-treatment pH correction Manganese oxidation Coagulation and flocculation Sedimentation clarification Filtration by granular medium Post treatment pH correction Chlorination disinfection Dewatering of wastewater | As required As required As required Regular Regular Regular Regular Regular Regular | Powdered activated carbon Sodium carbonate Potassium permanganate Aluminium sulphate - - Sodium hypochlorite Chlorine (gas) - |





Photo: Water Treatment Plant Operator conducts a jar test

Table 3: List of processes and chemicals used to treat and disinfect supplementary supply from Melbourne Water to Lance Creek clear water storage

| Source water/ Catchment | Storage/ Transfer | Treatment process | Treatment frequency | Added substances |
|--|--|---|---|--|
| Transfer from Silvan Reservoir without being treated at Silvan WTP | Cardinia Reservoir | Disinfection Fluoridation pH Correction Secondary disinfection Secondary pH correction | Regular Regular Regular Regular Regular | Chlorine gas (Cl ₂) Fluorosilicic acid (FSA) Lime (Calcium oxide) Sodium hypochlorite Carbon dioxide |
| Bass Strait sea water via Desalination Plant offtake | Direct to supply or Cardinia Reservoir | Coagulation Filtration Reverse osmosis Remineralisation Fluoridation Disinfection Sludge thickening Membrane preservations | Regular Regular Regular Regular Regular Regular Regular | Ferric sulphate, Sulfuric acid, PolyDADMAC* -- Antiscalant, Sodium hydroxide Hydrated lime (Calcium dioxide), Carbon dioxide Fluorosilicic acid (FSA) Sodium hypochlorite Ferric sulphate. Polyacrylamide Sodium bisulphite |
| Melbourne Water Delivery point 5 (DP5) of desalination pipeline | Transfer pipeline from DP5 to Lance Creek clear water storage tank | pH Correction Disinfection | As required As required | Hydrochloric Acid, Sodium hydroxide Chlorine gas (Cl ₂) |

*Polydiallyldimethylammonium chloride



Photos: SGW staff

Water Treatment Issues

Continual process monitoring and jar tests are used in water treatment plant laboratories to simulate plant conditions and ensure correct dosage of treatment chemicals. This enables optimisation of treatment processes in response to changes in raw water quality and other factors. Occasionally issues arise out of the application of water treatment processes and corrective actions must be taken.

Four fluoridation outages for periods greater than 72 hours at Lance Creek water treatment plant (WTP) are the only treatment issues noted for 2020-21. These were reported to the Department of Health in accordance with the Code of practice for fluoridation of drinking water supplies. The outages related to intentional shut-downs of the fluorosilicic acid dosing system; refer to Table 4.

Table 4: Fluoridation outages

| Issue | Location | Date | Summary |
|---|-----------------|-------------------------------|---|
| Fluoridation outage greater than 72 hours | Lance Creek WTP | 27/11/2020 to 1/12/2020 | Routine servicing of fluoridation system. For safety reasons, the system must be flushed with water for an extended period prior to servicing |
| Fluoridation outage greater than 72 hours | Lance Creek WTP | 27/3/2021 to 15/4/2021 | Electrical fault with fluoride analyser head (delays in sourcing replacement parts due to pandemic) |
| Fluoridation outage greater than 72 hours | Lance Creek WTP | 21/5/2021 to 27/5/2021 | Routine servicing of fluoridation system. For safety reasons, the system must be flushed with water for an extended period prior to servicing |
| Fluoridation outage greater than 72 hours | Lance Creek WTP | 18/6/2021 to 25/6/2021 | Expired fluoride extinguishers (delays in sourcing replacements due to pandemic) |

Quality Management Systems and Continual Improvement

Programs and practices

The risk management approach adopted by South Gippsland Water is based on the twelve elements of the Framework for Management of Drinking Water Quality as described in the *Australian Drinking Water Guidelines*. Several on-going programs and practices form part of the risk management system. These are designed to ensure treatment plants and water supply distribution systems are always operating optimally; examples are as follows:

- Filter management program
- Backflow prevention program
- Regular site security checks of all water treatment facilities and distribution system water storages
- Procedures in relation to hygienic mains break repair and replacement
- Proactive mains flushing and air-scouring programs
- Hydrant replacement program

The risk management system also includes a commitment to continual improvement, with the aim of achieving best practice in the delivery of drinking water. Training, attendance at seminars, and membership of peak industry bodies (including the Australian Water Association, the Water Industry Operators Association, and the Water Services Association of Australia) ensure all employees involved in water treatment and quality assurance are well-informed of drinking water-related research, and advances in technologies and practices.

Training highlights

Water treatment operators are required to complete formal training from an accredited provider upon employment (if not already qualified). Two operators successfully attained their Certificate III qualification in 2020-21. Another training highlight was the delivery of water quality awareness training to maintenance and other south Gippsland Water staff by Dr Peter Mosse. Such training is offered every few years to promote the importance of water quality across the business, and to complement internal training on hygienic water mains repair for maintenance staff.

Major improvements

While the on-going COVID-19 pandemic has seen delays on works, several improvement projects were completed in the 2020-21 year. These include replacement of the powder activated carbon (PAC) dosing system at Lance Creek and Foster water treatment plants. PAC is used to remove compounds produced by cyanobacteria (also known as “blue-green algae”) that cause taste and odour issues. The new PAC systems allow for greater monitoring and control of the dosing process, thus providing a more reliable barrier to these nuisance compounds. Also completed in 2020-21 was replacement of the geomembrane linings and covers for both the Fish Creek and Toora clear water storage basins. The geomembranes have a limited life-span (10 to 20 years) so periodic renewal is necessary for continuing protection of stored water. The renewal projects required considerable planning and work to ensure continuity of supply to customers while the basins were taken offline. Improvement works at Leongatha water treatment plant are also well underway. These and other

projects are summarised in Table 5 and will be discussed in more detail in future reports, once complete.

Table 5: Capital improvement projects –water treatment and supply

| Site | Improvement project | Water quality/supply benefit | Expected completion year | Approximate expenditure \$ | Status |
|-----------------------------|---|---|--------------------------|----------------------------|-------------|
| Foster WTP | Replacement of powdered activated carbon (PAC) dosing system | Improved taste and odour control | 2021 | \$50,000 | Complete |
| Lance Creek WTP | Replacement of powdered activated carbon (PAC) dosing system | Improved taste and odour control | 2021 | \$1,800,000 | Complete |
| Leongatha WTP | Installation of an ultraviolet light (UV) disinfection system | Provides an additional disinfection barrier against pathogenic microorganisms, particularly protozoan parasites | 2023 | \$1,400,000 | In progress |
| Leongatha WTP | Improvements to clear water storages configuration | Greater control of disinfectant contact times | 2023 | \$1,800,000 | In progress |
| Meeniyan WTP | Individual filter turbidity monitoring and control | Improved filtration monitoring and control of treatment process | 2022 | \$130,000 | Started |
| Toora WTP | Upgrade of the UV disinfection system | Improved reliability of existing system, which provides an additional barrier against pathogenic microorganisms, including protozoan parasites. | 2023 | \$70,000 | Not started |
| Fish Creek CWS Basin | Renewal of geomembrane lining and cover | Continued protection of potable water in basin | 2020 | \$450,000 | Complete |
| Toora CWS Basin | Renewal of geomembrane lining and cover | Continued protection of potable water in basin | 2021 | \$350,000 | Complete |
| Wonthaggi CWS Basin | Renewal of geomembrane lining and cover | Continued protection of potable water in basin | 2022 | \$150,000 | Started |
| Wonthaggi CWS Basin | Upgrade of pumps and pipework supplying water to Wonthaggi and Cape Paterson water towers | Surety of supply and greater contingency in the event of a power or storage failure. | 2021 | 1,750,000 | In progress |
| Dumbalk pump station | Upgrade of river offtake pump station | Surety of supply for Dumbalk | 2021 | \$200,000 | Complete |

3. Emergency, Incident, and Event Management

Incidents reported under the Safe Drinking Water Act

Section 22 of the *Safe Drinking Water Act 2003* (the Act) requires a water supplier to immediately notify the Department of Health (the Department) of any circumstances where it is believed that drinking water supplied to the public may be the cause of an illness, pose a risk to human health or cause widespread public complaint. Section 18 of the Act requires a water supplier to notify the Department when it becomes aware that the drinking water it is supplying to another person does not comply, or is not likely to comply, with any relevant water quality standard. Based on this requirement, the incidents described in this section have been reported to the Department in the 2020-21 reporting period. Table 6 provides a summary of the events reported under section 22. Further discussion is provided on the following pages. There were no events reported under section 18 in 2020-21.

Table 6: Summary of events reported to the Department of Health under section 22 of the Safe Drinking Water Act 2003

| Water sampling locality affected | Type of notification | Date of incident | Location of Incident | Nature of incident | Investigation result / Cause |
|----------------------------------|----------------------|------------------|---|---|---|
| Inverloch | Section 22 | 13/10/2020 | Mains break at Beachcomber Drive, Inverloch. Inverloch township affected. | Widespread public complaint due to colour and suspended sediments | Changes in pressure and flow due to a large water main break and emergency shutdown caused scouring of settled manganese sediments and biofilms within the distribution system. |
| Fish Creek | Section 22 | 17/12/2020 | Scouring of Fish Creek trunk main from WTP to Clearwater storage basin bypass. Fish Creek township affected | Potential for widespread public complaint due to colour and suspended sediments | Operation of a booster pump caused scouring of manganese sediments and biofilms within the Fish Creek trunk main |
| Poowong & Nyora | Section 22 | 29/3/2021 | Poowong clear water storage basin outlet and Customer tap sampling site in Follett Drive, Nyora | <i>Escherichia coli</i> (<i>E. coli</i>) detection for one routine sample collected from Poowong and one from Nyora | Results were not representative of the water being supplied in either town and determined as being false positive results. |

Widespread public complaint – Inverloch

A large water main break at Beachcomber Avenue, Inverloch, on the evening of the 13th October 2020 led to widespread public complaint in relation to colour and sediments. High flows and emergency shutdown of the affected main caused scouring of manganese sediments and biofilms across the southern, middle, and western sections of the town. Rapid risk assessment indicated that positive pressure in the system was maintained throughout the incident and there was no risk of contaminant ingress through backflow. The Department of Health was notified in accordance with section 22 of the Safe Drinking Water Act in relation to widespread public complaint. There were 34 colour complaints received from customers in relation to the incident.

Extensive flushing was carried out on the 13th to 14th October to remove colour and suspended sediments from the supply system. Results of disinfection residual monitoring and analysis of samples collected on the 14th October confirmed drinking water quality and safety.

Potential for widespread public complaint – Fish Creek

The Department of Health was notified under section 22 of the Safe Drinking Water Act of potential widespread complaint for Fish Creek on the 17th of December 2020. This followed unintended scouring of the trunk main which conveys water from storage at the Fish Creek water treatment plant to the town. Operation of booster pumps caused high velocity flow through the trunk main, stripping settled manganese sediments and biofilms from the inner surface. The result was a slug of blackish-coloured water that entered the town's reticulation.

At the time of the incident, the Fish Creek clear water storage basin was offline following relining and covering works. Normally, the basin would fill by gravity flow through the trunk main from the clear water storage tanks at the treatment plant, southeast of town. The pumps would run automatically to boost flow out of the basin during periods of high water demand. While the basin was offline, flow was gravity-fed directly from the storage at the treatment plant to the town's reticulation via basin bypass pipework. It was found that a small number of customers were experiencing drops in water pressure in relation to the changed supply condition during peak water usage times; hence operation of the booster pumps was deemed an appropriate action.

In response to the issue, the partially-refilled basin was brought back online so that the reticulation system could be flushed with clear water. The trunk main was isolated and also flushed of coloured water and sediments. Customers were advised of the issue via social media and word of mouth through staff working on the ground. A water tanker was set up in the centre of town so that customers could access clear drinking water while the remedial flushing was in progress. The coloured water issue was resolved by the afternoon of the 17th of December. Results of monitoring confirmed quality of the drinking water supply. While customer complaints with respect to colour and sediments were anticipated, none were received.

Air-scour cleaning of the Fish Creek trunk main has been prioritised for late 2021 to ensure any remaining sediments are removed. Given that the Fish Creek basin is now back online, recurrence of the booster pump related issue is unlikely.

***Escherichia coli* detections – Poowong and Nyora**

Escherichia coli (*E. coli*) were detected in two routine samples taken from the Lance Creek system on the 29th March 2021. The Poowong clear water storage basin outlet recorded a result of 1 orgs/100 mL, as did a customer tap sample in Nyora. The Department of Health was immediately notified per requirements of the Safe Drinking Water Act. In accordance with SGW's drinking water risk management plan, and the Act, a thorough investigation was conducted. This included confirmation of effective water treatment and disinfection processes, inspection of clear water storages, and review of works on the distribution system. An extensive monitoring program was also implemented on the 30th March 2021. Samples were collected from a total of 27 sites in the northern towns section of the Lance Creek system.

Investigation found no evidence of water treatment or disinfection failures. There had been no recent works that could have led to contamination of the supply system, and clear water storages were confirmed as secure. There were no further *E. coli* detections or other indicators of poor water quality for samples collected as part of the investigative monitoring program. Since no contributing factors could be identified, it was concluded that the low-level *E. coli* detections in Poowong and Nyora on the 29th March were false positive results. The detections were not representative of the water being supplied to the localities of Poowong and Nyora, or the connected supply of Loch. Thus, the localities remained compliant with the drinking water quality standard for *E. coli* in the 2020-21 reporting period.

Other potential issues

Central and south-eastern parts of Victoria were subject to a severe storm event on the 9th June 2021. Fierce winds downed trees and caused damage to electricity infrastructure resulting in widespread power outages and loss of telecommunications. Torrential rains flooded creeks and rivers leading to highly turbid source waters. South Gippsland Water implemented emergency management protocols in response to these challenges. Through use of generators at water treatment plants and careful management of treatment processes, drinking water quality remained uncompromised.

4. Drinking Water Quality Standards

During the 2020-21 reporting period, South Gippsland Water implemented water quality monitoring programs consistent with requirements of the *Safe Drinking Water Act 2003* (the Act) and associated Safe Drinking Water Regulations 2015 (the Regulations).

Schedule 2 of the Regulations lists three water quality parameters —*Escherichia coli*, trihalomethanes (total), and turbidity—and stipulates both the sampling frequency required for each parameter and the acceptable standard with which collected and tested samples must comply. As specified in the Regulations, mandatory samples must be collected from the drinking water supply at relevant frequencies and analysed for performance against water quality standards as shown in Table 7, below.

Table 7: Drinking water quality standards and required sampling frequencies as defined in Schedule 2 of the Safe Drinking Water Regulations 2015

| Parameter | Relevant sampling frequency for each water sampling locality | Quality standard for each water sampling locality |
|--------------------------------|--|--|
| <i>Escherichia coli</i> | One sample per week | <p>All samples of drinking water collected are found to contain no <i>Escherichia coli</i> per 100 millilitres of drinking water, with the exception of any false positive sample.</p> <p>For the purposes of this quality standard, a false positive sample means a sample that is found, after an analysis conducted in accordance with regulation 14, to contain <i>Escherichia coli</i> per 100 millilitres of drinking water, if---</p> <ul style="list-style-type: none"> a) following the analysis, the water supplier has conducted an investigation, which has been conducted in accordance with any guidelines issued by the Secretary in relation to such investigations, including any timeframes for commencement and completion of the investigations, to ascertain whether the results for the analysis are representative of water in the relevant sampling locality; and b) the water supplier has reported the results of the investigation to the Secretary in relation to such reports, including any timeframes for provision of the report; and c) the investigation has concluded that the results of the analysis conducted in accordance with regulation 14 were not representative of the water in the relevant water sampling locality because the investigation established that— <ul style="list-style-type: none"> (i) all other factors that would indicate the presence of <i>Escherichia coli</i> are not present in that water in the water sampling locality at the time of the investigation; and (ii) the drinking water treatment process applied, or other specified actions taken by the water supplier, are such as would be reasonably expected to have eliminated the presence of <i>Escherichia coli</i> in the water sampling locality at the relevant time; and (iii) all plant and infrastructure associated with the water treatment process were operating to specification at all relevant times; and (iv) there were no issues arising from degradation of plant or infrastructure in or around the relevant water sampling locality that could reasonably be suspected to have contributed to the presence of <i>Escherichia coli</i> in the drinking water in that water sampling locality. <p>A sample analysed in accordance with regulation 14 that is found, on that analysis, to contain <i>Escherichia coli</i> per 100 millilitres of drinking water is not a false positive sample unless all of the circumstances in paragraphs (a), (b) and (c) apply.</p> |
| Trihalomethanes (total) | One sample per month | Less than or equal to 0.25 milligrams per litre of drinking water |
| Turbidity | One sample per week | The 95 percentile of results for samples in any 12-month period must be less than or equal to 5.0 Nephelometric Turbidity Units |

Analysis Results – Schedule 2 parameters

The results of analysis for Schedule 2 parameters for 2020-21 are summarised in Tables 8 to 10.

Section 23 of the Act requires that a water supplier make available for inspection by the public the results of any water quality monitoring program that is conducted on any drinking water it supplies. Customers and members of the public may access drinking water quality data by telephoning South Gippsland Water Customer Service on 1300 851 636, or by emailing sgwater@sgwater.com.au

Escherichia coli

Escherichia coli (*E. coli*) is used as a specific indicator of faecal contamination to determine the safety of water for drinking. For the quality standard for each water sampling locality to be met with respect to *E. coli*, then all samples of drinking water collected must have been found to contain no *E. coli* per 100 millilitres of drinking water, with the exception of any false positive sample (refer to Table 6 above for definition of "false positive sample").

Results: *Escherichia coli*

Monitoring for *E. coli* for the 2020-21 reporting period was conducted in accordance with requirements of the Regulations and South Gippsland Water's risk-based monitoring program. The program specifies which sites are to be sampled and at what frequencies. Samples for *E. coli* analysis are collected weekly from a range of different sampling sites and locations including dedicated customer tap sites, clear water storages (CWS), and process water from water treatment plants. Other sites in distribution systems, such as upstream and downstream of secondary disinfection dosing units, and at the inlets and outlets of CWS tanks and basins are also sampled on a weekly or less-frequent basis.

Compliance with the water quality standard for *E. coli* is based on monitoring of drinking water as it is supplied to customers. For some localities, this includes the results of distribution clear water storage sample analysis (where there is not a more representative site downstream of the storage) in addition to those from customer tap sample analysis. All but one sample of drinking water collected were found to contain no *Escherichia coli* per 100 millilitres of drinking water. Results of *E. coli* compliance monitoring are presented in Table 7. Refer to part 3 for details on the detections of *E. coli* in the water sampling localities of Poowong and Nyora in March 2021.

Table 8: Escherichia coli results for 2020-21

| Water Sampling Locality | Minimum Customer tap sampling frequency (samples per time period) | Minimum Clear water storage outlet sampling frequency (samples per time period) | Total number of samples collected in compliance period | Maximum result (Orgs/100 mL) | Number of investigations | Number of samples where standard was not met |
|-------------------------|---|---|--|------------------------------|--------------------------|--|
| Alberton | one/week | - | 52 | 0 | 0 | 0 |
| Cape Paterson | one/week | one/week | 104 | 0 | 0 | 0 |
| Dumbalk | one/week | one/week | 104 | 0 | 0 | 0 |
| Fish Creek | one/week | one/week | 104 | 0 | 0 | 0 |
| Foster | one/week | one/week | 104 | 0 | 0 | 0 |
| Inverloch | two/week | one/week | 156 | 0 | 0 | 0 |
| Koonwarra | one/week | - | 52 | 0 | 0 | 0 |
| Korumburra | one/week | two/week | 156 | 0 | 0 | 0 |
| Lance Creek | one/week | one/week | 104 | 0 | 0 | 0 |
| Leongatha | two/week | one/week | 156 | 0 | 0 | 0 |
| Loch | one/week | one/week | 104 | 0 | 0 | 0 |
| Meeniyan | one/week | one/week | 104 | 0 | 0 | 0 |
| Nyora | one/week | - | 52 | 0 | 1 | 0* |
| Poowong | one/week | two/week | 156 | 0 | 1 | 0* |
| Port Franklin | one/week | - | 52 | 0 | 0 | 0 |
| Port Welshpool | one/week | - | 52 | 0 | 0 | 0 |
| Toora | one/week | two/week | 156 | 0 | 0 | 0 |
| Wonthaggi | two/week | one/week | 156 | 0 | 0 | 0 |
| Yarram | one/week | two/week | 156 | 0 | 0 | 0 |

*Investigation found that the samples were "false positive" and therefore standard was met; refer to Section 3 for information

Trihalomethanes

Trihalomethanes (THMs) are organic chemical compounds in which three of the four hydrogen atoms of methane (CH₄) are replaced by halogen atoms. The compounds may be present in drinking water principally because of chlorination or, to a much lesser extent, chloramination. Chlorine forms hypochlorous acid when added to water, and can react with naturally-occurring organic material to produce the trihalomethane species trichloromethane (chloroform), bromodichloromethane, dibromochloromethane, and tribromomethane (bromoform)

The ADWG states that, "Based on health considerations, the concentration of trihalomethanes, either individually or in total, in drinking water should not exceed 0.25 mg/L. Trihalomethane concentrations fluctuating occasionally (for a day or two annually) up to 1 mg/L are unlikely to pose a significant health risk. Action to reduce trihalomethanes is encouraged, but must not compromise disinfection, as non-disinfected water poses significantly greater risk than Trihalomethanes."

Total trihalomethanes results for 2020-21

For the year ending 30th June 2021, testing for trihalomethanes was conducted in accordance with the Regulations and South Gippsland Water's risk-based monitoring program. There were no exceedances of the regulatory limit of 0.25 mg/L; results are presented in Table 9.

Table 9: Trihalomethanes (total) results for 2020-21

| Water Sampling Locality | Customer tap sampling frequency (samples per time period) | Number of Clear water storage Outlet samples taken | Total number of samples collected in compliance period | Average result (mg/L) | Maximum result (mg/L) | Number of samples where standard was not met |
|-------------------------|---|--|--|-----------------------|-----------------------|--|
| Alberton | one/month | 0 | 12 | 0.049 | 0.100 | 0 |
| Cape Paterson | one/month | 0 | 12 | 0.064 | 0.087 | 0 |
| Dumbalk | one/month | 0 | 12 | 0.076 | 0.130 | 0 |
| Fish Creek | one/month | 12 | 24 | 0.152 | 0.200 | 0 |
| Foster | one/month | 0 | 12 | 0.083 | 0.100 | 0 |
| Inverloch | one/month | 0 | 12 | 0.060 | 0.086 | 0 |
| Koonwarra | one/month | 0 | 12 | 0.104 | 0.160 | 0 |
| Korumburra | one/month | 0 | 12 | 0.056 | 0.088 | 0 |
| Lance Creek | one/month | 0 | 12 | 0.046 | 0.081 | 0 |
| Leongatha | one/month | 0 | 12 | 0.102 | 0.150 | 0 |
| Loch | one/month | 0 | 12 | 0.049 | 0.066 | 0 |
| Meeniyan | one/month | 0 | 12 | 0.090 | 0.120 | 0 |
| Nyora | one/month | 0 | 12 | 0.066 | 0.086 | 0 |
| Poowong | one/month | 0 | 12 | 0.053 | 0.075 | 0 |
| Port Franklin | one/month | 0 | 12 | 0.094 | 0.130 | 0 |
| Port Welshpool | one/month | 0 | 12 | 0.068 | 0.083 | 0 |
| Toora | one/month | 0 | 12 | 0.075 | 0.120 | 0 |
| Wonthaggi | one/month | 0 | 12 | 0.059 | 0.085 | 0 |
| Yarram | one/month | 0 | 12 | 0.040 | 0.088 | 0 |

Turbidity

Turbidity is the measurement of the light-scattering property of water which is dependent on the amount, size, and composition of fine suspended matter. The Safe Drinking Water Regulations 2015 specify that the 95th percentile of results for samples in any 12-month period must be less than or equal to 5.0 Nephelometric Turbidity Units (NTU).

Results: Turbidity

Monitoring for compliance with the water quality standard for turbidity was conducted in accordance with the Regulations and South Gippsland Water's risk-based monitoring program. Turbidity results are presented in Table 10.

Table 10: Turbidity Results 2020-21

| Water Sampling Locality | Customer tap sampling frequency (samples per time period) | Total number of samples collected in compliance period | Maximum turbidity in a sample (NTU) | Maximum 95 th percentile of turbidity results in any 12 months | Number of 95 th percentile of results in any 12 months above standard |
|-------------------------|---|--|-------------------------------------|---|--|
| Alberton | one/week | 52 | 0.5 | 0.2 | 0 |
| Cape Paterson | one/week | 52 | <0.1 | 0.1 | 0 |
| Dumbalk | one/week | 52 | 0.5 | 0.1 | 0 |
| Fish Creek | one/week | 52 | <0.1 | 0.2 | 0 |
| Foster | one/week | 52 | <0.1 | 0.2 | 0 |
| Inverloch | two/week | 104 | <0.1 | 0.1 | 0 |
| Koonwarra | one/week | 52 | 0.2 | 0.1 | 0 |
| Korumburra | one/week | 52 | 0.3 | 0.2 | 0 |
| Lance Creek | one/week | 52 | <0.1 | 0.2 | 0 |
| Leongatha | two/week | 104 | 0.2 | 0.2 | 0 |
| Loch | one/week | 52 | <0.1 | 0.1 | 0 |
| Meeniyian | one/week | 52 | 0.2 | 0.1 | 0 |
| Nyora | one/week | 52 | <0.1 | 0.1 | 0 |
| Poowong | one/week | 52 | 0.2 | 0.1 | 0 |
| Port Franklin | one/week | 52 | <0.1 | 0.2 | 0 |
| Pt Welshpool | one/week | 52 | 0.2 | 0.2 | 0 |
| Toora | one/week | 52 | 0.2 | 0.2 | 0 |
| Wonthaggi | two/week | 104 | 0.4 | 0.1 | 0 |
| Yarram | one/week | 52 | <0.1 | 0.1 | 0 |

Analysis Results - Other water quality standards (algal toxin, pathogen, chemical or substance that may pose a risk to human health)

As part of South Gippsland Water's drinking water quality management system, water quality parameters with potential to affect human health are monitored. These parameters are measured against standard values defined in the *Australian Drinking Water Guidelines 2011* (ADWG).

As many of these parameters do not change significantly over time or through water supply systems, frequent monitoring is not required. Results are summarised in Tables 10 to 26.

Section 23 of the Act requires that a water supplier make available for inspection by the public the results of any water quality monitoring program that is conducted on any drinking water it supplies. Customers and members of the public may access drinking water quality data by telephoning South Gippsland Water Customer Service on 1300 851 636, or by emailing sgwater@sgwater.com.au



Photos: Water Quality Officers carry out routine weekly water supply monitoring in Loch

Aluminium (total)

Aluminium may be present in drinking water where aluminium salts are used as coagulants in water treatment processes to destabilise particles in water. Water quality performance with respect to aluminium was measured against the ADWG aesthetic guideline value of 0.2 mg/L. As stated in the ADWG, "no health-based guideline is set for aluminium at this time, but this issue will be kept under review." A summary of aluminium (total) results is presented in Table 11.

Table 11: Aluminium (Total) results 2020-21

| Water Sampling Locality | Minimum frequency of sampling (samples per time period) | Customer Tap samples collected | Aesthetic drinking water quality guideline (mg/L) | Average result (mg/L) | Maximum Result (mg/L) | Number of samples where guideline was not met |
|-------------------------|---|--------------------------------|---|-----------------------|-----------------------|---|
| Alberton | one/month | 12 | 0.2 | 0.04 | 0.24* | 0 |
| Cape Paterson | one/month | 12 | 0.2 | 0.02 | 0.03 | 0 |
| Dumbalk | one/month | 12 | 0.2 | <0.01 | <0.01 | 0 |
| Fish Creek | one/month | 12 | 0.2 | 0.02 | 0.04 | 0 |
| Foster | one/month | 12 | 0.2 | <0.01 | <0.01 | 0 |
| Inverloch | one/month | 12 | 0.2 | 0.02 | 0.04 | 0 |
| Koonwarra | one/month | 12 | 0.2 | 0.02 | 0.03 | 0 |
| Korumburra | one/month | 12 | 0.2 | 0.02 | 0.04 | 0 |
| Lance Creek | one/month | 12 | 0.2 | 0.02 | 0.05 | 0 |
| Leongatha | one/month | 12 | 0.2 | 0.01 | 0.03 | 0 |
| Loch | one/month | 12 | 0.2 | 0.03 | 0.05 | 0 |
| Meeniyan | two/month | 12 | 0.2 | 0.07 | 0.16 | 0 |
| Nyora | one/month | 12 | 0.2 | 0.02 | 0.05 | 0 |
| Poowong | one/month | 12 | 0.2 | 0.02 | 0.04 | 0 |
| Port Franklin | one/month | 12 | 0.2 | 0.02 | 0.02 | 0 |
| Pt. Welshpool | one/month | 12 | 0.2 | 0.02 | 0.02 | 0 |
| Toora | one/month | 12 | 0.2 | 0.02 | 0.03 | 0 |
| Wonthaggi | one/month | 12 | 0.2 | 0.02 | 0.03 | 0 |
| Yarram | one/month | 12 | 0.2 | 0.01 | 0.03 | 0 |

*In response to slight exceedance of aesthetic guideline in Alberton on the 4th August 2020, mains flushing was conducted. Review and optimisation of coagulant dosing at the supplying Devon north water treatment plant was also carried out.

Arsenic

Arsenic is a naturally-occurring element which can be introduced to water through dissolution of minerals and ores, or from industrial effluent, atmospheric deposition, drainage from old gold mines or the use of some types of sheep dip. The ADWG specify that, from a health perspective, the concentration of arsenic should not exceed 0.01 mg/L. Water supplied by South Gippsland water complied with the ADWG guideline value for arsenic, with all results indicating levels were below detection limits; refer to Table 12.

Table 12: Arsenic results for 2020-21

| Water treatment plant / system | Locality supplied | Sampling frequency (samples per time period) | Total number of samples | Drinking water quality guideline (mg/L) | Result (mg/L) | Number of samples where guideline was not met |
|--------------------------------|---|--|-------------------------|---|---------------|---|
| Devon North | Alberton Yarram | one/year | 1 | 0.01 | <0.001 | 0 |
| Dumbalk | Dumbalk | one/year | 1 | 0.01 | <0.001 | 0 |
| Fish Creek | Fish Creek | one/year | 1 | 0.01 | <0.001 | 0 |
| Foster | Foster | one/year | 1 | 0.01 | <0.001 | 0 |
| Korumburra | Korumburra | one/year | 1 | 0.01 | <0.001 | 0 |
| Lance Creek | Cape Paterson Inverloch Lance Creek Wonthaggi | one/year | 1 | 0.01 | <0.001 | 0 |
| Leongatha | Leongatha Koonwarra | one/year | 1 | 0.01 | <0.001 | 0 |
| Meeniyah | Meeniyah | one/year | 1 | 0.01 | <0.001 | 0 |
| Poowong | Loch Nyora Poowong | one/year | 1 | 0.01 | <0.001 | 0 |
| Toora | Port Franklin Pt Welshpool Toora | one/year | 1 | 0.01 | <0.001 | 0 |

Copper

Copper is naturally distributed in rocks and soils. It may also be present in drinking water where aggressive waters of low pH and hardness induce corrosion of copper pipes. The ADWG specify that the concentration of copper should not exceed 1 mg/L based on aesthetic considerations, and 2 mg/L based on health considerations. Water supplied by South Gippsland Water complied with both the aesthetic-based and health-based guideline values for copper; refer to Table 13.

Table 13: Copper results for 2020-21

| Water Sampling Locality | Frequency of sampling (samples per time period) | Customer Tap samples collected | Drinking water quality health guideline (mg/L) | Average result (mg/L) | Maximum result (mg/L) | Number of samples where guideline was not met |
|-------------------------|---|--------------------------------|--|-----------------------|-----------------------|---|
| Alberton | one/quarter | 4 | 2 | <0.001 | <0.001 | 0 |
| Cape Paterson | one/quarter | 4 | 2 | 0.005 | 0.006 | 0 |
| Dumbalk | one/quarter | 4 | 2 | 0.004 | 0.006 | 0 |
| Fish Creek | one/quarter | 4 | 2 | 0.003 | 0.005 | 0 |
| Foster | one/quarter | 4 | 2 | 0.008 | 0.016 | 0 |
| Inverloch | one/quarter | 4 | 2 | 0.007 | 0.014 | 0 |
| Koonwarra | one/quarter | 4 | 2 | 0.010 | 0.013 | 0 |
| Korumburra | one/quarter | 4 | 2 | 0.008 | 0.016 | 0 |
| Lance Creek | one/quarter | 4 | 2 | 0.016 | 0.031 | 0 |
| Leongatha | one/quarter | 4 | 2 | 0.006 | 0.012 | 0 |
| Loch | one/quarter | 4 | 2 | 0.005 | 0.007 | 0 |
| Meeniyan | one/quarter | 4 | 2 | 0.005 | 0.007 | 0 |
| Nyora | one/quarter | 4 | 2 | 0.006 | 0.008 | 0 |
| Poowong | one/quarter | 4 | 2 | 0.005 | 0.007 | 0 |
| Port Franklin | one/quarter | 4 | 2 | 0.002 | 0.004 | 0 |
| Pt. Welshpool | one/quarter | 4 | 2 | 0.004 | 0.006 | 0 |
| Toora | one/quarter | 4 | 2 | 0.006 | 0.013 | 0 |
| Wonthaggi | one/quarter | 4 | 2 | 0.007 | 0.010 | 0 |
| Yarram | one/quarter | 4 | 2 | 0.002 | 0.003 | 0 |

Note: Samples are taken for analysis from the reticulation system. Copper levels may be higher at the customers' internal taps if copper plumbing is used in the domestic system. Customers experiencing blue copper staining of fixtures or discolouration of water are advised to call South Gippsland Water Customer Service on 1300 851 636.

Cyanogen chloride

Cyanogen chloride is a byproduct of chloramination that can be formed through the reaction between organic precursors with hypochlorous acid in the presence of the ammonium ion. Based on health considerations, the ADWG specify that the concentration of total cyanogenic compounds in drinking water should not exceed 0.08 mg/L.

Monitoring of chloraminated water systems confirmed that water supplied by South Gippsland Water complied with the guideline value for cyanogen chloride, with all results indicating levels were below the detection limit; refer to Table 14.

Table 14: Cyanogen chloride for 2020-21: chloraminated systems only

| Water Treatment plant / system | Locality supplied | Frequency of sampling (samples per time period) | Number of samples collected | Drinking water quality guideline (mg/L) | Average Result (mg/L) | Number of samples where guideline was not met |
|--------------------------------|---|---|-----------------------------|---|-----------------------|---|
| Devon North | Alberton Yarram | one/year | 1 | 0.01 | <0.05 | 0 |
| Lance Creek | Cape Paterson Inverloch Korumburra Lance Creek Loch Nyora Poowong Wonthaggi | three/year | 3 | 0.01 | <0.05 | 0 |

Chlorine disinfection residual (Free or Total Chlorine)

Disinfection is a critical part of water treatment. Not all microorganisms can be removed during clarification and filtration processes so an additional “kill-step” is required to ensure drinking water safety. Chlorine and chloramine (compounds formed from chlorine and ammonia) are the most commonly used agents. These are applied in carefully controlled dosages at treatment plants in the process known as primary disinfection.

The actual amount of disinfection agent dosed is very small (to visualise, think of about a cup’s worth in a swimming pool). It is just adequate to both inactivate microorganisms that have made it through the purification process, and to confer a disinfection residual on the water. The residual helps to protect water as it passes through the pipes and storages of the distribution system. Chlorine and, to a lesser extent, chloramine tend to dissipate with time and distance through a water supply network so secondary dosing units may be used to ensure water remains protected to the ends of the system.

Disinfection agent dosing is automatically controlled by on-line monitoring systems which shut-down treatment plant operation in the event of levels being either too low or too high. This prevents out-of-specification water from being produced while the problem is addressed. With these controls in place, water supplied to customers is unlikely to ever exceed the ADWG guideline. The main purpose of disinfection residual monitoring is to ensure that it remains at an adequate level throughout the distribution system. There is no guideline for minimum disinfection residual and what is considered acceptable is particular to an individual water supply system based on its size and components, as well as the results of microbiological monitoring results.

South Gippsland Water uses both chlorine and chloramine disinfection. Chlorine dissociates in water to form free chlorine, which consists of aqueous molecular chlorine, hypochlorous acid and hypochlorite ion. Free chlorine is monitored in the reticulation systems of chlorinated supplies on a (minimum) weekly basis during routine sampling. For the chloraminated supplies, total chlorine is monitored. Total chlorine is the sum of chlorine in combined form (with ammonia and other nitrogenous or organic compounds) and free chlorine.

Based on health considerations, the ADWG guideline value for total chlorine in drinking water is 5 mg/L. There is no specific guideline for free chlorine; however, in chlorinated systems free chlorine generally approximates total chlorine. As both total and free chlorine levels are well below 5 mg/L, all localities can be assumed to be compliant with the water quality guideline for total chlorine; refer to tables 15 and 16.

Table 15: Free Residual Chlorine for 2020-21 (chlorinated localities)

| Water sampling locality | Minimum sampling frequency (samples per time period) | Total number of samples | Minimum result * (mg/L) | Average result (mg/L) | Maximum result (mg/L) | Number of samples where guideline was not met |
|-------------------------|--|-------------------------|-------------------------|-----------------------|-----------------------|---|
| Alberton | one/week | 39* | 0.01 | 0.95 | 1.67 | 0 |
| Dumbalk | one/week | 52 | 0.02 | 0.34 | 0.81 | 0 |
| Fish Creek | one/week | 52 | 0.02 | 0.35 | 0.89 | 0 |
| Foster | one/week | 51** | 0.12 | 0.45 | 1.07 | 0 |
| Koonwarra | one/week | 52 | 0.00 | 0.02 | 0.08 | 0 |
| Leongatha | two/week | 104 | 0.01 | 0.50 | 1.39 | 0 |
| Meeniyan | one/week | 52 | 0.00 | 0.39 | 0.93 | 0 |
| Port Franklin | one/week | 52 | 0.01 | 0.55 | 1.01 | 0 |
| Pt. Welshpool | one/week | 98 | 0.10 | 0.95 | 1.53 | 0 |
| Toora | one/week | 51** | 0.49 | 0.95 | 1.34 | 0 |
| Yarram | one/week | 39* | 0.07 | 1.30 | 1.91 | 0 |

Table 16: Total Chlorine for 2020-21 (chloraminated localities)

| Water sampling locality | Minimum sampling frequency (samples per time period) | Total number of samples | Minimum result * (mg/L) | Average result (mg/L) | Maximum Result** (mg/L) | Number of samples where standard was not met |
|-------------------------|--|-------------------------|-------------------------|-----------------------|-------------------------|--|
| Alberton | one/week | 24** | 0.76 | 1.81 | 2.18 | 0 |
| Cape Paterson | one/week | 52 | 0.25 | 1.33 | 1.91 | 0 |
| Inverloch | two/week | 114 | 0.19 | 1.67 | 2.30 | 0 |
| Korumburra | two/week | 101 | 0.71 | 1.74 | 2.14 | 0 |
| Lance Creek | one/week | 52 | 1.50 | 2.20 | 3.20 | 0 |
| Loch | one/week | 61 | 0.48 | 1.20 | 1.69 | 0 |
| Nyora | one/week | 63 | 0.59 | 1.46 | 1.83 | 0 |
| Poowong | one/week | 52 | 0.10 | 1.01 | 1.95 | 0 |
| Wonthaggi | two/week | 104 | 0.51 | 1.61 | 2.10 | 0 |
| Yarram | one/week | 25** | 1.57 | 1.87 | 2.20 | 0 |

*Low minimum results are generally recorded at dead-end main or other low water usage sites (e.g. that supply farms) and are addressed with mains flushing to freshen up supply. Corresponding microbiological results indicated no decline in drinking water safety due to low disinfection residual results recorded.

**High maximum results are generally recorded close to sites of primary or secondary disinfection at the entry point (start) of the distribution system

Fluoride

Naturally-occurring fluoride concentrations in drinking water are dependent on the type soil and rock through which source water drains. Fluoride may also be added to drinking water supplies as a public health measure for the prevention of dental decay. The Australian Drinking Water Guidelines 2011 (ADWG) specify that the maximum concentration of fluoride in drinking water should not exceed 1.5 mg/L. Under the *Health (fluoridation) Act*, fluoride added to drinking water must not result in an average optimum concentration in excess of one part per million parts of water.

The Code of practice for fluoridation of drinking water supplies (2018) made under the *Health (Fluoridation) Act 1973* states that a water agency must not add fluoride to an extent that results in an average optimum concentration in excess of one part fluoride per million parts of water (1.0 mg/L) over any 12-month period in any water sampling locality.

Results: Fluoride in non-fluoridated supplies

Monitoring of non-fluoridated drinking water is conducted annually to verify continued low levels of naturally-occurring fluoride, as have been recorded historically. Results of fluoride monitoring for non-fluoridated supplies are provided in Table 17.

Table 17: Fluoride results for non-fluoridated supplies for 2020-21

| Water treatment plant / system | Locality supplied | Sampling frequency (samples per time period) | Total number of samples | Drinking water quality standard (mg/L) | Result (mg/L) | Number of samples where standard was not met |
|--------------------------------|------------------------------------|--|-------------------------|--|---------------|--|
| Devon North | Alberton Yarram | one/year | 1 | 1.5 | 0.05 | 0 |
| Dumbalk | Dumbalk | one/year | 1 | 1.5 | 0.07 | 0 |
| Fish Creek | Fish Creek | one/year | 1 | 1.5 | <0.05 | 0 |
| Foster | Foster | one/year | 1 | 1.5 | <0.05 | 0 |
| Leongatha | Leongatha Koonwarra | one/year | 1 | 1.5 | 0.06 | 0 |
| Meeniyan | Meeniyan | one/year | 1 | 1.5 | 0.06 | 0 |
| Toora | Port Franklin Port Welshpool Toora | one/year | 1 | 1.5 | <0.05 | 0 |

Results: Fluoride in fluoridated supplies

For the fluoridated supply system of Lance Creek, monitoring is conducted in accordance with the Code of practice for fluoridation of drinking water supplies (2018) under the *Health (fluoridation) Act 1973*. Refer to Table 18 for results.

Table 18: Results: Fluoride in fluoridated supply for 2020-21

| Water sampling locality | Frequency of sampling (samples per time period) | Total Number of samples | Drinking water quality guideline (mg/L) | Operating target range mg/L | Average * result mg/L | Maximum result mg/L | Number of samples where standard was not met |
|-------------------------|---|-------------------------|---|-----------------------------|-----------------------|---------------------|--|
| Cape Paterson | one/week | 52 | 1.5 | 0.9±0.1 | 0.76 | 0.89 | 0 |
| Inverloch | one/week | 52 | 1.5 | 0.9±0.1 | 0.75 | 0.90 | 0 |
| Korumburra | one/week | 52 | 1.5 | 0.9±0.1 | 0.75 | 0.89 | 0 |
| Lance Creek | one/week | 52 | 1.5 | 0.9±0.1 | 0.76 | 0.92 | 0 |
| Loch | one/week | 52 | 1.5 | 0.9±0.1 | 0.76 | 0.88 | 0 |
| Nyora | one/week | 52 | 1.5 | 0.9±0.1 | 0.76 | 0.93 | 0 |
| Poowong | one/week | 52 | 1.5 | 0.9±0.1 | 0.75 | 0.92 | 0 |
| Wonthaggi | one/week | 52 | 1.5 | 0.9±0.1 | 0.76 | 0.93 | 0 |

* Note: under s. 5(3) of the Health (Fluoridation) Act 1973 fluoride added to drinking water must not result in an average optimum concentration in excess of one part fluoride per million parts of water.

Lead

Lead may be detected in drinking water as a result of dissolution from natural sources or from household plumbing systems containing lead. The ADWG specify that, from a health perspective, the concentration of lead should not exceed 0.01 mg/L. Water supplied by South Gippsland Water complied with the ADWG guideline value; refer to Table 19.

Table 19: Lead results for 2020-21

| Water sampling locality | Frequency of sampling (samples per time period) | Total number of samples | Drinking water quality standard (mg/L) | Average result (mg/L) | Maximum result (mg/L) | Number of samples where standard was not met |
|-------------------------|---|-------------------------|--|-----------------------|-----------------------|--|
| Alberton | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Cape Paterson | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Dumbalk | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Fish Creek | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Foster | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Inverloch | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Koonwarra | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Korumburra | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Lance Creek | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Leongatha | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Loch | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Meeniyan | one/quarter | 4 | 0.01 | <0.001 | 0.001 | 0 |
| Nyora | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Poowong | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Port Franklin | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Pt Welshpool | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Toora | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Wonthaggi | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Yarram | one/quarter | 4 | 0.01 | <0.001 | <0.001 | 0 |

Manganese

Manganese may be present in source waters as a result of dissolution from natural sources. Concentrations may be reduced in drinking water by converting soluble forms of the element to insoluble precipitates followed by physical removal using filtration. The ADWG specify that the concentration of manganese should not exceed 0.1 mg/L based on aesthetic considerations, and 0.5 mg/L based on health considerations. Drinking water supplied by South Gippsland Water complied with both the aesthetic and health guidelines for manganese; refer to Table 20.

Table 20: Manganese for 2020-21

| Water sampling locality | Minimum Frequency of sampling (samples per time period) | Total number of samples collected* | Drinking water quality health guideline (mg/L) | Minimum result (mg/L) | Average result (mg/L) | Maximum result (mg/L) | Number of samples where guideline was not met |
|-------------------------|---|------------------------------------|--|-----------------------|-----------------------|-----------------------|---|
| Alberton | one/month | 12 | 0.5 | <0.001 | <0.001 | <0.001 | 0 |
| Cape Paterson | one/month | 12 | 0.5 | <0.001 | 0.003 | 0.004 | 0 |
| Dumbalk | one/month | 12 | 0.5 | <0.001 | 0.001 | 0.002 | 0 |
| Fish Creek | one/month | 12 | 0.5 | 0.001 | 0.002 | 0.005 | 0 |
| Foster | one/month | 12 | 0.5 | <0.001 | <0.002 | 0.005 | 0 |
| Inverloch | one/month | 12 | 0.5 | 0.001 | 0.003 | 0.005 | 0 |
| Koonwarra | one/month | 12 | 0.5 | 0.001 | 0.002 | 0.004 | 0 |
| Korumburra | one/month | 12 | 0.5 | 0.001 | 0.004 | 0.008 | 0 |
| Lance Creek | one/month | 12 | 0.5 | 0.001 | 0.003 | 0.006 | 0 |
| Leongatha | one/month | 12 | 0.5 | 0.001 | 0.003 | 0.005 | 0 |
| Loch | one/month | 12 | 0.5 | 0.001 | 0.002 | 0.004 | 0 |
| Meeniyah | one/month | 12 | 0.5 | 0.001 | 0.001 | 0.003 | 0 |
| Nyora | one/month | 12 | 0.5 | 0.001 | 0.003 | 0.006 | 0 |
| Poowong | one/month | 12 | 0.5 | 0.001 | 0.003 | 0.005 | 0 |
| Port Franklin | one/month | 12 | 0.5 | 0.001 | 0.004 | 0.008 | 0 |
| Pt Welshpool | one/month | 12 | 0.5 | 0.001 | 0.003 | 0.007 | 0 |
| Toora | one/month | 12 | 0.5 | 0.002 | 0.006 | 0.024 | 0 |
| Wonthaggi | one/month | 12 | 0.5 | 0.001 | 0.004 | 0.008 | 0 |
| Yarram | one/month | 12 | 0.5 | <0.001 | <0.001 | <0.001 | 0 |

Nitrate and Nitrite

Nitrates and nitrites are naturally-occurring oxides of nitrogen. Nitrite is rapidly oxidised to nitrate and is seldom present in well-oxygenated or chlorinated supplies. Chloramination disinfection can lead to nitrate and nitrite formation in the distribution system due to the action of nitrifying bacteria. The ADWG specify that, from a health perspective, the concentrations of nitrate and nitrite should not exceed 50 mg/L and 3 mg/L respectively. Monitoring for oxidised nitrogen (nitrate plus nitrite) was conducted on a quarterly basis in chlorinated South Gippsland Water systems in 2020-21. The standard of 50 mg/L for nitrate was used to measure water quality performance for oxidised nitrogen given nitrite's rapid conversion to nitrate. Based on nitrification risk, more frequent specific analysis for both nitrate and nitrite was conducted in the chloraminated localities. All the chloraminated localities complied with the specific guideline values for nitrate and nitrite; refer to Tables 21, 22 and 23.

Table 21: Oxidised nitrogen (nitrate + nitrite) for 2020-21 (chlorinated supplies only)

| Water treatment plant / system | Localities supplied | Sampling frequency | Total number of samples | Minimum Result (mg/L) | Maximum Result mg/L | Number of samples where standard was not met |
|--------------------------------|---|--------------------|-------------------------|-----------------------|---------------------|--|
| Dumbalk | Dumbalk | one/quarter | 4 | 0.02 | 1.10 | 0 |
| Fish Creek | Fish Creek | one/quarter | 4 | 0.26 | 0.36 | 0 |
| Foster | Foster | one/quarter | 4 | 0.09 | 0.42 | 0 |
| Leongatha | Leongatha Koonwarra | one/quarter | 4 | 0.22 | 0.84 | 0 |
| Meeniyah | Meeniyah | one/quarter | 4 | 0.14 | 0.81 | 0 |
| Toora | Port Franklin Post Welshpool Toora | one/quarter | 4 | 0.08 | 0.94 | 0 |
| Devon North | Alberton Yarram | one/quarter | 2* | 0.37 | 1.1 | 0 |

*Results provided for samples taken post change to chlorination disinfection for Devon North system

Table 22: Nitrate for 2020-21 (chloraminated localities only)

| Water sampling locality | Minimum sampling frequency | Total number of samples | Minimum result (mg/L) | Maximum result (mg/L) | Number of samples where guideline was not met |
|-------------------------|----------------------------|-------------------------|-----------------------|-----------------------|---|
| Alberton | one per month | 5* | 0.950 | 1.20 | 0 |
| Cape Paterson | one per month | 12 | 0.010 | 0.56 | 0 |
| Inverloch | one per month | 12 | 0.013 | 0.56 | 0 |
| Korumburra | two per month | 36 | 0.007 | 0.57 | 0 |
| Lance Creek | one per month | 12 | <0.003 | 0.56 | 0 |
| Loch | one per month | 12 | 0.048 | 0.57 | 0 |
| Nyora | one per month | 12 | 0.011 | 0.56 | 0 |
| Poowong | one per month | 12 | 0.010 | 0.61 | 0 |
| Wonthaggi | one per month | 12 | 0.009 | 0.55 | 0 |
| Yarram | one per month | 5* | 0.370 | 1.20 | 0 |

*Results provided for samples taken prior to change to chlorination disinfection for Alberton and Yarram

Table 23: Nitrite for 2020-21 (Chloraminated localities only)

| Water sampling locality | Minimum sampling frequency | Total number of samples | Minimum result (mg/L) | Maximum result (mg/L) | Number of samples where guideline was not met |
|-------------------------|----------------------------|-------------------------|-----------------------|-----------------------|---|
| Alberton | one per month | 5* | 0.004 | 0.016 | 0 |
| Cape Paterson | one per month | 12 | 0.002 | 0.014 | 0 |
| Inverloch | one per month | 12 | 0.002 | 0.006 | 0 |
| Korumburra | two per month | 36 | <0.002 | 0.004 | 0 |
| Lance Creek | one per month | 12 | <0.002 | 0.002 | 0 |
| Loch | one per month | 12 | 0.004 | 0.290 | 0 |
| Nyora | one per month | 12 | 0.002 | 0.006 | 0 |
| Poowong | one per month | 12 | <0.002 | 0.004 | 0 |
| Wonthaggi | one per month | 12 | <0.002 | 0.003 | 0 |
| Yarram | one per month | 5* | 0.002 | 0.015 | 0 |

*Results provided for samples taken prior to change to chlorination disinfection for Alberton and Yarram

Nitrosodimethylamine (NDMA)

N-Nitrosodimethylamine (NDMA) is produced as a byproduct of chloramination of drinking water due to the oxidation of natural organic matter by chlorine in the presence of ammonia. The ADWG specify that, based on health considerations, the concentration of NDMA in drinking water should not exceed 0.0001 mg/L (100 ng/L).

Monitoring of chloraminated systems for NDMA was conducted quarterly, with results indicating water supplied by South Gippsland Water complied with the guideline value for NDMA; refer to Table 23.

Table 24: NDMA in chloraminated supplies for 2020-21

| Water treatment plant /system | Localities supplied | Sampling frequency (samples per time period) | Total number of samples | Average Result (mg/L) | Number of samples where standard was not met |
|-------------------------------|--|--|-------------------------|-----------------------|--|
| Lance Creek | Cape Paterson Inverloch Korumburra Lance Creek Loch Nyora Poowong Wonthaggi | three/year | 3 | <0.000003 | 0 |

Other inorganic chemicals

Inorganic chemicals may be present in water as a result of the natural dissolution of rocks, soils and some plants, or through contamination from industrial and agricultural sources. Materials used to coat pipes and plumbing fittings may also be sources of inorganic chemicals in drinking water. Monitoring of all water supply systems was conducted to verify compliance with ADWG health-related guidelines for chemical concentrations as specified in Table 25.

Table 25: Other inorganic chemicals for 2020-21

| Parameter | Sampling frequency | Number of samples per water system/locality* | Total Number of samples taken in 2020-21 | ADWG guideline value (mg/L) | Maximum results (mg/L) | Number of samples where standard was not met |
|------------|--------------------|--|--|-----------------------------|------------------------|--|
| Antimony | Annually | one per locality | 19 | 0.003 | <0.001 | 0 |
| Barium | Annually | one per locality | 19 | 2 | 0.031 | 0 |
| Beryllium | Annually | one per locality | 19 | 0.06 | <0.001 | 0 |
| Boron | Annually | one per locality | 19 | 4 | 0.11 | 0 |
| Cadmium | Annually | one per locality | 19 | 0.002 | <0.0002 | 0 |
| Chromium | Annually | one per locality | 19 | 0.05 | <0.001 | 0 |
| Cobalt | Annually | one per locality | 19 | - | <0.001 | 0 |
| Cyanide | Annually | one per system | 8 | 0.08 | <0.005 | 0 |
| Mercury | Annually | one per locality | 19 | 0.001 | <0.001 | 0 |
| Molybdenum | Annually | one per locality | 19 | 0.05 | <0.001 | 0 |
| Nickel | Annually | one per locality | 19 | 0.02 | <0.001 | 0 |
| Selenium | Annually | one per locality | 19 | 0.01 | <0.001 | 0 |
| Silver | Annually | one per locality | 19 | 0.1 | <0.001 | 0 |
| Sulphate | Quarterly | one per system | 32 | 500 | 59 | 0 |
| Zinc | Annually | one per locality | 19 | 3 | 0.008 | 0 |

*Monitoring may be conducted at the entry point to distribution systems or at customer tap sites in each locality dependent on likelihood of change in level of chemical as it passes through the water supply system.

Other organic chemicals

Potential sources of contamination of the drinking water supply with organic chemicals are industrial effluent, run-off from agricultural land, and the use of pesticides and herbicides. Organic disinfection by-products, such as the chloroacetic acids, can also form as result of disinfection processes.

Consistent with historical data, monitoring of raw water intakes, distribution entry point water or customer tap sites found that levels of organic chemicals were compliant with the ADWG health-related guidelines for the 2020-21 period; refer to Table 26.

Table 26: Organic chemical monitoring results for 2020-21

| Parameter | Sampling frequency | Number of samples per water supply system/locality* | Total Number of samples taken in 2020-21 | ADWG Guideline value mg/L | Maximum results mg/L | Number of samples where guideline was not met |
|----------------------------|--------------------|---|--|---------------------------|----------------------|---|
| 1,1-dichloroethane | Annually | One per system | 8 | a | <0.001 | - |
| 1,2-dichloroethane | Annually | One per system | 8 | 0.003 | <0.001 | 0 |
| 2,4,5-T | Annually | One per system | 8 | 0.1 | <0.00001 | 0 |
| 2,4,5-TP | Annually | One per system | 8 | b | <0.00001 | - |
| 2,4,6-T | Annually | One per system | 8 | b | <0.0001 | - |
| 2,4,6-trichlorophenol | Annually | One per system | 8 | 0.02 | <0.001 | 0 |
| 2,4-D | Annually | One per system | 8 | 0.03 | 0.00008 | 0 |
| 2,4-DB | Annually | One per system | 8 | b | <0.00001 | - |
| 2,4-DP | Annually | One per system | 8 | b | <0.00001 | - |
| 2,6-D | Annually | One per system | 8 | b | <0.0001 | - |
| 4-Chlorophenoxyacetic Acid | Annually | One per system | 8 | b | <0.00001 | - |
| Atrazine | Annually | One per system | 8 | 0.02 | <0.002 | 0 |
| Benzene | Annually | One per system | 8 | 0.001 | <0.001 | 0 |
| Benzo(a)pyrene | Annually | One per system** | 4 | 0.00001 | <0.000002 | 0 |
| Total PAH | Annually | One per system** | 4 | b | <0.00001 | - |
| Carbon tetrachloride | Annually | One per system | 8 | 0.003 | <0.001 | 0 |
| Chloroacetic acid | Annually | One per locality | 19 | 0.15 | <0.005 | 0 |
| Clopyralid | Annually | One per system | 8 | 2 | <0.00005 | 0 |
| Dicamba | Annually | One per system | 8 | 0.1 | <0.00001 | 0 |
| Dichloroacetic acid | Annually | One per locality | 19 | 0.1 | 0.043 | 0 |
| Fluroxypyr | Annually | One per system | 8 | b | <0.00005 | - |
| Glyphosate | Annually | One per system | 8 | 1 | <0.03 | 0 |
| MCPA | Annually | One per system | 8 | 0.04 | <0.00001 | 0 |
| MCPB | Annually | One per system | 8 | b | <0.00001 | - |
| Mecoprop | Annually | One per system | 8 | b | <0.00001 | - |
| Metsulfuron methyl | Annually | One per system | 8 | 0.04 | <0.0001 | 0 |
| Pentachlorophenol | Annually | One per system | 8 | 0.01 | <0.001 | 0 |
| Picloram | Annually | One per system | 8 | 0.3 | 0.00005 | 0 |
| Prometryn | Annually | One per system | 8 | b | <0.002 | - |
| Simazine | Annually | One per system | 8 | 0.02 | <0.002 | 0 |
| Tetrachloroethene | Annually | One per system | 8 | 0.05 | <0.001 | 0 |
| Trichloroacetic acid | Annually | One per locality | 19 | 0.1 | 0.041 | 0 |
| Triclopyr | Annually | One per system | 8 | 0.02 | 0.00010 | 0 |

Table notes:

a Insufficient data to set an ADWG guideline value based on health considerations

b No ADWG information available

* Monitoring is conducted at raw water inlets to treatment plants or at clear water storage outlets to distribution systems

** Monitoring conducted at Devon North, Lance Creek and Leongatha water treatment plants only

Raw water monitoring

For the purposes of risk management, the parameters listed in Table 27 were monitored in raw water at the specified (minimum) frequencies by external laboratory analysis in raw water at all South Gippsland Water treatment plants for the 2020-21 reporting period.

Table 27: Raw water monitoring frequencies

| Parameter | Sampling frequency |
|--|---|
| <i>Escherichia coli</i> | Weekly |
| Total Coliforms | Weekly |
| Cryptosporidium | Event-based |
| Giardia | Event-based |
| Cyanobacteria (Blue-green algae) | Weekly (external/internal) |
| Algae byproducts (MIB/Geosmin/Saxitoxin) | Event-based |
| Alkalinity | Monthly |
| Aluminium | Quarterly |
| Calcium | Quarterly |
| Copper | Quarterly |
| Dissolved Organic Carbon | Quarterly |
| Manganese | Quarterly |
| Nitrogen | Quarterly |
| Orthophosphorous | Quarterly |
| Total Organic Carbon | Quarterly |
| Turbidity | Weekly |
| Pesticides | Annually/Biannually/Event-based |
| Radionuclides | Every 7 years: Sampling conducted in 2016 |


Data obtained from all water quality monitoring programs conducted by South Gippsland Water is available on request by telephoning Customer Service on 1300 5682 0444 or emailing sgwater@sgwater.com.au

Aesthetics

South Gippsland Water strives to provide drinking water that is consistently clear and pleasant to drink for all customers. Actions taken to manage aesthetic characteristics include:

- Optimisation of treatment processes to minimise levels of iron, manganese, and organic compounds in supplied water
- pH adjustment of treated water
- Regular flushing and air-scouring to remove sediment accumulation in mains
- Frequent sampling and analysis for aesthetic parameters
- Monitoring and management of algal blooms in raw water reservoirs
- Monitoring when required for compounds that may impart unpleasant tastes and odours to drinking water

Results of monitoring for aesthetic characteristics are provided in Tables 28 to 33 on the following pages.



Photos: Members of SGW's friendly customer service team

Colour

Water may appear coloured due to the presence of natural organic substances including humic and fulvic acids, and dissolved inorganics, such as iron and manganese. Based on aesthetic considerations, the ADWG specifies that colour should not exceed 15 Hazen Units (HU). Water supplied by South Gippsland Water complied with the guideline value for colour; refer to Table 28.

Table 28: True Colour Results for 2020-21

| Water treatment plant / system | Localities supplied | Minimum sampling frequency (samples per time period) | Total number of samples | Average result (HU) | Maximum result (HU) | Number of samples where guideline was not met |
|--------------------------------|--|--|-------------------------|---------------------|---------------------|---|
| Devon North | Alberton Yarram | one/quarter | 4 | <2 | 4 | 0 |
| Dumbalk | Dumbalk | one/quarter | 4 | <2 | 4 | 0 |
| Fish Creek | Fish Creek | one/quarter | 4 | <2 | 4 | 0 |
| Foster | Foster | one/quarter | 4 | <2 | 2 | 0 |
| Lance Creek | Cape Paterson Inverloch Korumburra Lance Creek Loch Nyora Poowong Wonthaggi | one/quarter | 4 | <2 | 4 | 0 |
| Leongatha | Leongatha Koonwarra | one/quarter | 4 | <2 | 4 | 0 |
| Meeniyan | Meeniyan | one/quarter | 4 | <2 | 2 | 0 |
| Toora | Port Franklin Port Welshpool Toora | one/quarter | 4 | <2 | 4 | 0 |

Iron

Iron is present in source waters due to dissolution of soil and rock. High iron concentrations in drinking water can occur through rusting of iron pipes and fittings. Based on aesthetic considerations, the ADWG specify that the concentration of iron should not exceed 0.3 mg/L. Water supplied by South Gippsland Water complied with the guideline value for iron; refer to Table 29.

Table 29: Iron results for 2020-21

| Water sampling locality | Frequency of sampling (samples per time period) | Total number of samples | Minimum result mg/L | Maximum result mg/L | Number of samples where guideline was not met |
|-------------------------|---|-------------------------|---------------------|---------------------|---|
| Alberton | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Cape Paterson | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Dumbalk | one/quarter | 4 | 0.01 | 0.04 | 0 |
| Fish Creek | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Foster | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Inverloch | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Koonwarra | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Korumburra | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Lance Creek | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Leongatha | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Loch | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Meeniyan | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Nyora | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Poowong | one/quarter | 4 | <0.01 | 0.02 | 0 |
| Port Franklin | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Port Welshpool | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Toora | one/quarter | 4 | <0.01 | 0.01 | 0 |
| Wonthaggi | one/quarter | 4 | <0.01 | <0.01 | 0 |
| Yarram | one/quarter | 4 | <0.01 | 0.02 | 0 |

Alkalinity

Alkalinity is defined as the quantitative capacity of an aqueous solution to neutralise an acid. In simpler terms, it is a measure of how easily the pH of water can be changed. Alkalinity is mainly determined by the levels of carbonate, bicarbonate and hydroxyl anions (negatively-charged ions) present. The property of alkalinity has a strong influence on what is referred to as water stability, which is the tendency of water to be corrosive, stable, or scale-forming on contact with surfaces.

Water stability is complex and influenced by a number of factors, but in general soft water of low pH and low alkalinity will tend to corrode surfaces. Highly corrosive (aggressive) water is not desirable in that it can lead to the leaching of copper and other metals from pipes and plumbing fittings.

In contrast, hard water of high pH and high alkalinity will generally tend to deposit calcium carbonate (form scale) on pipes, plumbing fittings and hot water systems. While encrustation of pipes and fittings is not desirable for obvious reasons, a thin layer of calcium carbonate can be beneficial in that it provides protection against corrosion in conditions of changing water stability.

There are no specific standards for alkalinity in drinking water but as this property provides resistance against changes in pH that can lead to either corrosion or excessive encrustation, a reasonable level should be maintained in drinking water supplies. What is reasonable for a particular type of water will depend mainly upon its other characteristics of pH and hardness, but a value in the range of 50 to 200 mg/L CaCO₃ is generally considered to be optimal.

Results of alkalinity monitoring are provided in Table 30.

****Explanatory note on units used to express both alkalinity and hardness properties***

Calcium carbonate equivalent (mg/L CaCO₃) is the value obtained when taking into account the different characteristics in relation to reactivity (ability to combine) of various salts, such that the overall effect is the same as that produced by the expressed concentration of calcium carbonate. This allows for a convenient method of comparison in chemistry. As both alkalinity and hardness are aggregate properties created by the combined effects of different salts, the calcium carbonate equivalent unit is used in each case. This does not mean, however, that alkalinity and hardness are the same property. Alkalinity is chemically defined as the sum of all titratable bases in a solution, whereas hardness is the sum of all polyvalent cation (ions having more than one positive charge) concentrations in a solution. With respect to a solution made purely from the compound calcium carbonate, therefore, the property of alkalinity is due to the component carbonate anion (a base), while the property of hardness is due to the component calcium cation.

Table 30: Alkalinity Results for 2020-21

| Water treatment plant / system | Localities supplied | Minimum sampling frequency (samples per time period) | Total number of samples | Minimum result (mg/L as CaCO ₃)* | Average result (mg/L as CaCO ₃)* | Maximum result (mg/L as CaCO ₃)* |
|--------------------------------|--|--|-------------------------|--|--|--|
| Devon North | Alberton Yarram | one/quarter | 4 | 19 | 22 | 25 |
| Dumbalk | Dumbalk | one/quarter | 4 | 41 | 59 | 82 |
| Fish Creek | Fish Creek | one/quarter | 4 | 36 | 37 | 38 |
| Foster | Foster | one/quarter | 4 | 39 | 42 | 43 |
| Lance Creek | Cape Paterson Inverloch Korumburra Lance Creek Loch Nyora Poowong Wonthaggi | one/quarter | 4 | 30 | 54 | 68 |
| Leongatha | Leongatha Koonwarra | one/quarter | 4 | 35 | 43 | 48 |
| Meeniyah | Meeniyah | one/quarter | 4 | 41 | 53 | 61 |
| Toora | Port Franklin Post Welshpool Toora | one/quarter | 4 | 41 | 44 | 47 |

**refer to explanatory note in text above*

Hardness

Hardness is a measure of the concentration of calcium and magnesium ions in water. To minimise undesirable build-up of scale in hot water systems, the ADWG specifies that total hardness (as calcium carbonate) in drinking water should not exceed 200 mg/L. Water supplied by South Gippsland Water complied with the guideline value for hardness; refer to Table 31.

Table 31: Total Hardness in calcium carbonate (CaCO₃) equivalents* for 2020-21

| Water treatment plant / system | Localities supplied | Sampling frequency (samples per time period) | Total number of samples | Minimum result (mg/L as CaCO ₃)* | Average result (mg/L as CaCO ₃)* | Maximum result (mg/L as CaCO ₃)* | Number of samples where guideline was not met |
|--------------------------------|--|--|-------------------------|--|--|--|---|
| Devon North | Alberton Yarram | one/quarter | 4 | 16 | 21 | 25 | 0 |
| Dumbalk | Dumbalk | one/quarter | 4 | 61 | 86 | 110 | 0 |
| Fish Creek | Fish Creek | one/quarter | 4 | 23 | 28 | 32 | 0 |
| Foster | Foster | one/quarter | 4 | 33 | 34 | 37 | 0 |
| Lance Creek | Cape Paterson Inverloch Korumburra Lance Creek Loch Nyora Poowong Wonthaggi | one/quarter | 4 | 18 | 54 | 78 | 0 |
| Leongatha | Leongatha Koonwarra | one/quarter | 4 | 47 | 54 | 71 | 0 |
| Meeniyah | Meeniyah | one/quarter | 4 | 68 | 72 | 77 | 0 |
| Toora | Port Franklin Port Welshpool Toora | one/quarter | 4 | 28 | 33 | 39 | 0 |

*Refer to explanatory note on units in alkalinity section on previous pages.

pH

The property of pH relates to the hydrogen ion concentration of water. pH is measured on a logarithmic scale from 0 to 14. A pH of 7 is neutral, a pH greater than 7 is alkaline, and a pH less than 7 is acidic.

To reduce corrosion and encrustation in pipes and fittings, the ADWG specifies that the pH of drinking water should be between 6.5 and 8.5. The ADWG also states that new concrete tanks and cement-mortar lined pipes can significantly increase pH and a value up to 9.2 may be tolerated, provided monitoring indicates no deterioration in microbiological quality.

The reference to microbiological quality is made in the ADWG since the disinfecting power of chlorine in chlorinated systems is greatest at lower pH and gradually declines as pH increases. Significant impairment of chlorine disinfection occurs above pH 8.0. The results for pH in chlorinated systems are provided in Table 32. Based on mean pH values, all localities complied with the aesthetic guideline. One sample taken from the locality of Alberton in January 2021 (post change to chlorination disinfection -see part 2 for information) recorded a value above the upper guideline of 9.2. This was due to low water usage at the affected site, which is supplied from a cement mortar-lined main. Mains flushing was carried out to remove aged water from the system. There were no indicators of microbiological deterioration in relation to the increased pH.

The chemistry (and the effect of pH) for chloramination disinfection differs from that of chlorination. A higher pH is beneficial in a chloraminated system as it slows the natural decay of monochloramine and prevents the formation of dichloramine and trichloramine, which can cause unpleasant tastes and odours. A consequence of maintaining a higher pH is that occasional exceedance of the ADWG guideline can occur. pH results for chloraminated localities is provided in Table 33. Based on mean values, all localities complied with the guideline for pH. One sample taken from the locality of Alberton recorded a value above the guideline in September 2020 (prior to the change to chlorination disinfection – see part 2 for more information). As per above, this can be attributed to low water usage in the locality, and supply from cement mortar-lined mains. A site in Yarram also recorded a pH above the upper guideline of 9.2 in October 2020. The affected site is located in an industrial area where there is low water usage and pockets of aged water. In both cases, mains flushing was implemented in response to the exceedances.

Table 32: pH results for chlorinated system in 2020-21

| Water sampling locality | Minimum frequency of sampling (samples per time period) | Total number of samples | Minimum result pH | Mean result pH | Maximum result pH | Number of samples not compliant with aesthetic guideline |
|-------------------------|---|-------------------------|-------------------|----------------|-------------------|--|
| Alberton* | one/week | 39 | 7.6 | 8.4 | 9.6 | 1 |
| Dumbalk | one/week | 52 | 7.8 | 8.1 | 8.3 | 0 |
| Fish Creek | one/week | 52 | 6.5 | 7.8 | 8.2 | 0 |
| Foster | one/week | 52 | 7.4 | 7.6 | 7.9 | 0 |
| Koonwarra | one/week | 52 | 7.6 | 7.8 | 8.0 | 0 |
| Leongatha | two/week | 104 | 7.3 | 7.6 | 8.0 | 0 |
| Meeniyana | one/week | 52 | 7.4 | 7.7 | 8.0 | 0 |
| Port Franklin | one/week | 52 | 7.7 | 8.2 | 9.1 | 0 |
| Port Welshpool | one/week | 52 | 7.2 | 7.6 | 8.0 | 0 |
| Toora | one/week | 52 | 7.2 | 7.6 | 8.0 | 0 |
| Yarram* | one/week | 39 | 7.2 | 8.1 | 9.1 | 0 |

*For samples collected in period post change to chlorination for the Yarram-Alberton system (9th November 2020 to 30th June 2021)

Table 33: pH results for chloraminated localities in 2020-21

| Water sampling locality | Minimum frequency of sampling (samples per time period)* | Total number of samples | Minimum result pH | Mean result pH | Maximum result pH | Number of samples not compliant with aesthetic guideline |
|-------------------------|--|-------------------------|-------------------|----------------|-------------------|--|
| Alberton* | one per week | 22 | 8.2 | 8.8 | 9.4 | 1 |
| Cape Paterson | one per week | 52 | 7.9 | 8.2 | 8.6 | 0 |
| Inverloch | two per week | 114 | 7.7 | 8.0 | 8.2 | 0 |
| Korumburra | two per week | 64 | 7.8 | 8.1 | 8.7 | 0 |
| Lance Creek | one per week | 52 | 7.3 | 7.9 | 8.2 | 0 |
| Loch | one per week | 61 | 8.0 | 8.3 | 8.8 | 0 |
| Nyora | one per week | 62 | 7.9 | 8.1 | 8.8 | 0 |
| Poowong | one per week | 52 | 7.7 | 8.1 | 8.6 | 0 |
| Wonthaggi | two per week | 104 | 7.8 | 8.1 | 8.6 | 0 |
| Yarram* | one per week | 22 | 7.7 | 8.4 | 9.3 | 1 |

*For samples collected in period prior to change to chlorination for the Yarram-Alberton system (1st July to 9th November 2020)

Analysis of results

Comparison of results for Schedule 2 parameters over three years

A comparison of compliance with water quality standards specified in Schedule 2 of the Safe Drinking Water Regulations 2015 in the 2020-21 period with that of the previous two fiscal years is presented in Figure 2. Consistent compliance across all South Gippsland Water water sampling localities is illustrated and in measure with the water quality standards listed in Schedule 2 of the Regulations for *Escherichia coli*, Trihalomethanes and Turbidity.




Figure 2: Percentage of localities where the drinking water complied with the water quality standards for *Escherichia coli*, trihalomethanes and turbidity

Comparison of results of other water quality parameters over three years

A comparison of results for the 2020-21 reporting period and the previous two financial years for water quality parameters other than those listed in Schedule 2 of the Safe Drinking Water Regulations 2015 is presented in Table 33. The comparison is based on percentage compliance with the guideline values of the *Australian Drinking Water Guidelines 2011*.

Table 34: Percentage of samples compliant with health-related guidelines from the ADWG

| Water Quality Parameter | Percentage of samples compliant with health-related guidelines from the <i>Australian Drinking Water Guidelines 2011</i> | | |
|-------------------------|--|---------------|---------------|
| | 2018-19 | 2019-20 | 2020-21 |
| Arsenic | 100 % | 100 % | 100 % |
| Aluminum | 100 % | 100 % | 100 % |
| Chlorine | 100 % | 100 % | 100 % |
| Copper | 100 % | 100 % | 100 % |
| Cyanogen chloride | 100 % | 100 % | 100 % |
| Iron | 100 % | 100 % | 100 % |
| Lead | 100 % | 100 % | 100 % |
| Manganese | 100 % | 100 % | 100 % |
| Nitrate | 100 % | 100 % | 100 % |
| Nitrite | 100 % | 100 % | 100 % |
| NDMA | 100 % | 100 % | 100 % |
| Antimony | 100 % | 100 % | 100 % |
| Barium | 100 % | 100 % | 100 % |
| Beryllium | 100 % | 100 % | 100 % |
| Boron | 100 % | 100 % | 100 % |
| Cadmium | 100 % | 100 % | 100 % |
| Chloroacetic acid | 100 % | 100 % | 100 % |
| Chromium | 100 % | 100 % | 100 % |
| Cyanide | 100 % | 100 % | 100 % |
| Dichloroacetic acid | 100 % | 100 % | 100 % |
| Mercury | 100 % | 100 % | 100 % |
| Molybdenum | 100 % | 100 % | 100 % |
| Nickel | 100 % | 100 % | 100 % |
| Selenium | 100 % | 100 % | 100 % |
| Silver | 100 % | 100 % | 100 % |
| Sulphate | 100 % | 100 % | 100 % |
| Trichloroacetic acid | 100 % | 100 % | 100 % |
| Zinc | 100 % | 100 % | 100 % |
| 1,2-dichloroethane | 100 % | 100 % | 100 % |
| 2,4,5-T | 100 % | 100 % | 100 % |
| 2,4,6-trichlorophenol | 100 % | 100 % | 100 % |
| 2,4-D | 100 % | 100 % | 100 % |
| Atrazine | 100 % | 100 % | 100 % |
| Benzene | 100 % | 100 % | 100 % |
| Benzo(a)pyrene | 100 % | 100 % | 100 % |
| Carbon tetrachloride | 100 % | 100 % | 100 % |
| Clopyralid | 100 % | 100 % | 100 % |
| Dicamba | 100 % | 100 % | 100 % |
| Glyphosate | 100 % | 100 % | 100 % |
| MCPA | 100 % | 100 % | 100 % |
| Metsulfuron methyl | 100 % | 100 % | 100 % |
| Pentachlorophenol | 100 % | 100 % | 100 % |
| Picloram | 100 % | 100 % | 100 % |
| Simazine | 100 % | 100 % | 100 % |
| Tetrachloroethene | 100 % | 100 % | 100 % |
| Triclopyr | 100 % | 100 % | 100 % |
| Gross Alpha * | 100 % | Not monitored | Not monitored |
| Gross Beta * | 100 % | Not monitored | Not monitored |

*Radiological parameters monitored once every seven years as per risk-based monitoring program. No monitoring occurred in the 2020-21 reporting period.

5. Complaints relating to water quality for 2020-21

South Gippsland Water records and attends to all complaints relating to drinking water quality to ensure the highest level of customer satisfaction. Table 35 below illustrates the four complaint types and the number of complaints received for each type over the 2020-21 year. Determination of the number of complaints per 100 customers supplied is based on the number of complaints compared with the total number of connected properties. A comparison of the number complaints with that of the previous two reporting periods is provided in Table 36. Complaints for 2020-21 are broken down into complaint type per locality and supply system in Table 37.

Table 35: Customer complaints for 2020-21

| Type of complaint | Number of complaints | Number of complaints per 100 customers (connected properties) supplied |
|---------------------------|----------------------|--|
| Dirty/discoloured water | 50 | 0.22 |
| Taste and/or odour | 17 | 0.08 |
| Air in water | 4 | 0.02 |
| Alleged/suspected illness | 1 | 0.00 |
| Other | 9 | 0.04 |
| Total complaints | 81 | 0.36 |

Table 36: Complaints comparison of 2020-21 with the previous two reporting periods

| Type of complaint | Number of Complaints | | | Comparison with previous reporting period | Comments |
|-------------------------|--------------------------|--------------------------|--------------------------|---|--|
| | 2018-19 reporting period | 2019-20 reporting period | 2020-21 reporting period | | |
| Dirty/discoloured Water | 41 | 27 | 50 | Moderately significant increase | Increase for 2020-21 can be attributed to a large water main break in Inverloch in Oct 2020. Changes in pressure and flow caused scouring of settled mineral sediments in the supply system, resulting in a high number of complaints over a short period (1-2 days). |
| Taste/odour | 32 | 20 | 17 | Slight decrease | Sustained low number of complaints in 2020-21 can be largely attributed to improved ability to mitigate the effects of algal blooms in Lance Creek Reservoir. This includes use of supplemental supply from Melbourne water grid, and improved treatment technologies. Water network cleaning programs have also contributed to low complaint level. |
| Air in Water | 9 | 14 | 4 | Moderately significant decrease | Complaints have followed water mains break repair. The decline in complaints for 2020-21 may be attributed to suspension of air-scour cleaning programs due to the Covid-19 pandemic and related "lockdowns". |
| Alleged illness | 2 | 1 | 1 | No change | Category includes general queries re water quality and health concerns. No evidence provided or found that supplied drinking water was cause. |
| Other | 3 | 8 | 9 | No significant change | Complaints include problems with aquatic animal pets, corrosion of internal household plumbing or appliances, general concerns about the use of chlorine, etc. |
| Total | 87 | 70 | 81 | See above | See above comments and "Management of complaints" discussion on following pages. |

Table 37: Customer complaints per complaint type and locality for 2020-21

| Water treatment plant / supply system | Water sampling locality | Complaint category | | | | | Total complaints per locality | Total complaints per supply system |
|---------------------------------------|-------------------------|------------------------------|--------------------|--------------|-----------------|----------|-------------------------------|------------------------------------|
| | | Colour / "Dirty Water" water | Taste and/or odour | Air in water | Alleged illness | Other | | |
| Devon North | Alberton | 1 | 0 | 0 | 1 | 0 | 2 | 5 |
| | Yarram | 1 | 1 | 0 | 0 | 1 | 3 | |
| Dumbalk | Dumbalk | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Fish Creek | Fish Creek | 1 | 0 | 0 | 0 | 0 | 1 | 1 |
| Foster | Foster | 1 | 1 | 0 | 0 | 0 | 2 | 2 |
| Lance Creek (southern towns) | Cape Paterson | 0 | 0 | 0 | 0 | 0 | 0 | 57 |
| | Inverloch | 34 | 0 | 1 | 0 | 1 | 36 | |
| | Lance Creek | 0 | 1 | 0 | 0 | 0 | 1 | |
| | Wonthaggi | 1 | 1 | 2 | 0 | 3 | 7 | |
| Lance Creek (northern towns) | Korumburra | 4 | 3 | 0 | 0 | 2 | 9 | 4 |
| | Loch | 0 | 1 | 0 | 0 | 0 | 1 | |
| | Nyora | 0 | 1 | 1 | 0 | 0 | 2 | |
| | Poowong | 0 | 0 | 0 | 0 | 1 | 1 | |
| Leongatha | Koonwarra | 0 | 0 | 0 | 0 | 0 | 0 | 4 |
| | Leongatha | 3 | 1 | 0 | 0 | 0 | 4 | |
| Meeniyan | Meeniyan | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Toora | Port Franklin | 1 | 2 | 0 | 0 | 0 | 3 | 12 |
| | Port Welshpool | 2 | 2 | 0 | 0 | 0 | 4 | |
| | Toora | 1 | 3 | 0 | 0 | 1 | 5 | |
| Total complaints per category | | 50 | 17 | 4 | 1 | 9 | 81 | 81 |



Photos: SGW staff

Management of complaints

Colour / “Dirty Water”

Colour / “Dirty Water” complaints relate to problems with the clarity of water. Tap water that contains sediments or particles and is coloured yellow, brown or blackish hues is often reported as “dirty water” by the customer. The particles and colour are produced by manganese and other mineral oxides rather than what might commonly be referred to as “dirt” (i.e. soil, mud, sewerage), but the overall effect is that water appears dirty and is unacceptable to the customer. Complaints in this category include reports of stained laundry items which may result from oxidation of minerals in contact with laundry detergents in a washing machine.

Dirty/discoloured water complaints primarily result from:

- High manganese levels in source waters. The soil in the South Gippsland region is naturally high in manganese, and run-off into reservoirs and rivers is unavoidable. Not all manganese can be removed during the water treatment process so accumulation in the distribution system can occur;
- Accumulation of sediment within clear water storages and water mains over time; and/or
- Unintended scouring of water mains following high flows or recharging of the system.

Corrective actions to address dirty/discoloured water include:

- Use of aeration and potassium permanganate dosing systems at water treatment plants to oxidise manganese and maximise physical removal through filtration;
- Cleaning of clear water storage tanks and basins
- Implementation of scheduled air-scouring and flushing programs within all water sampling localities to remove manganese and other accumulated sediments;
- Additional flushing when required in response to individual complaints, and increased frequency of flushing regimes for problem areas.
- Provision of a commercial cleaning product which removes discolouration marks from laundry items in response to individual customer complaints.

There were 50 complaints received in relation to dirty/discoloured water in the 2020-21 reporting period. The increase from the previous reporting period (see Table 35) can be attributed to the large water main break event of October 2020. There were 34 complaints received from Inverloch customers in relation to this event. Changes in pressure and flow caused by the break and valve closures to isolate the broken main caused scouring of settled mineral sediments. Refer to section 3 for further details.

Taste and odour

What is considered acceptable in terms of the flavour and smell of water has some level of individual subjectivity. For instance, some customers object to the taste and odour of chlorine, while others receiving water with the same chlorine concentration do not. This may be because the objecting customers sense the chlorine taste and odour more acutely than others, or because they perceive chlorine as something they don't want to drink. While tastes and odours in drinking water do not generally denote that the water is unsafe, South Gippsland Water endeavours to minimise unpleasant

flavours as much as possible. This is important not only for the customer's satisfaction and enjoyment but also so that they will choose supplied tap water over other potentially less-safe/healthful forms of hydration (e.g. from a poorly-managed tank water system, or from sugary soft drinks) or options having adverse environmental impacts (i.e., purchased bottled water).

Taste and odour complaints result primarily from:

- Cyanobacterial (blue-green algal) compounds in the water;
- Manganese and/or iron sediment in the water;
- Changes in pH, dissolved oxygen, and other factors in relation to ageing of water within a water main due to low flows.
- Chlorine in water.

Corrective actions to prevent or address taste and odour issues include:

- Routine monitoring of supplied water for taste and odour, manganese, iron, turbidity, pH and chlorine;
- Analysis for taste and odour related parameters (as above) when required in response to individual complaints;
- Use of powdered activated carbon (PAC) at treatment plants to remove algae-related and other taste and odour compounds from water;
- Use of aeration and potassium permanganate dosing systems at water treatment plants to oxidise manganese and maximise removal from source waters.
- Water main flushing and air-scouring programs
- Use of supplementary supply where available (i.e., Melbourne water for Lance Creek system)

There were 17 complaints relating to taste and odour issues received from customers in 2020-21. From a historical perspective, this can be considered a good outcome. The observed decline in taste and odour complaints in the past three years (refer to Table 35) can be largely attributed to the connection of the Lance Creek system to the Melbourne water supply grid. The ability to supply the system with 100% Melbourne water has allowed the Lance Creek Reservoir to be taken completely offline when affected by cyanobacterial blooms. The capacity to blend Melbourne and Lance Creek waters has also enabled dilution of cyanobacterial taste and odour compounds in the reservoir to levels acceptable to customers.

Air in water

Air in water complaints are mostly received following mains breaks or the implementation of air-scour mains cleaning programs. While notification is given to residents prior to air-scouring, customers may become concerned at the 'milky' appearance of water. Customers are advised that the white colour of the water is due to the presence of tiny air-bubbles and that flushing through a tap for a few minutes should correct the problem. If the problem cannot be resolved by the customer, mains flushing is carried out.

There were 4 complaints involving air in water from South Gippsland Water customers in the 2020-21 reporting period. These followed mains break repairs.

Alleged illness

Customers may make an alleged illness complaint if they suspect supplied tap water is the cause of illness or other conditions, such as skin or eye irritation. In general, a customer will call to seek reassurance with regards to water quality rather than alleging that the water is the cause of their health problem. Customers with health concerns are encouraged to consult a medical professional for diagnosis and treatment. Depending on the nature of the complaint, additional monitoring to verify quality of drinking water supplied to the customer's residence and through the domestic plumbing system may be carried out. Details of the complaint and results of both monitoring and diagnostic testing (if provided) are recorded via an Illness Complaint Record Form. In the unlikely event of supplied drinking water being found to be a causative factor of illness, the Department of Health would be immediately notified. Further actions, which might include issuing of a boil water advisory, would be implemented as a matter of the highest priority.

There was one call received in relation to skin irritation for 2020-21. The customer was exploring possible causes of the irritation. Investigation, including review of water quality data and other customer complaints (there were none similar), found no evidence that the drinking water supply was the cause of the issue.

Other complaints

Other complaints relate to concerns that are beyond the control and responsibility of South Gippsland Water, such as problems with aquarium fish or garden plants, and issues with domestic plumbing or appliances. In response to such complaints, results of monitoring programs that may be relevant are reviewed, and additional investigation and sampling is carried out where appropriate. Customers are informed of the likelihood of supplied water being the cause of the problem and given advice on where to seek additional assistance if required. There were nine calls in this category for 2020-21.



6. Findings of the most recent risk management plan audit

Under section 7 of the Safe Drinking Water Act 2003 (the Act), a water supplier is required to prepare, implement, and review a risk management plan for the supply of drinking water to the public. The plan must be audited by an approved external auditor periodically as directed by the Department of Health. An audit was scheduled to take place in April 2020; however, due to the Covid-19 pandemic, it was postponed until August 2020. Audit outcomes are discussed below.


South Gippsland Water (SGW) was found to be compliant in all auditable elements for the period 28th April 2018 to 28th August 2020. Highlights, as noted by the auditor, are provided below:

- The success to date of the use of the novel algaecide to help control cyanobacteria and their metabolites is commended.
- The move to more robust PAC dosing systems to help control cyanobacteria and their metabolites with greater reliability is commended.
- The efforts of SGW to protect the reservoir riparian areas and inner catchments, and improvements to water quality and reduced operating costs arising, are impressive and are highly commended.
- The efforts to reduce risks from pathogens by implementing UV disinfection upgrades where warranted, and the careful planning efforts to target those investments, are commended.
- The standard of general housekeeping at depots, WTPs and network sites audited was high and is commended.

While no nonconformities were recorded, the auditor identified some opportunities for improvement (OFIs) for SGW consideration; these are as follows:

- Consideration could be given to the possible value of roofing of the (Leongatha) WTP infrastructure to improve ease of maintenance and asset life and reduce slime formation.
- SGW may wish to keep track of emerging issues relating to microbial pathogens and disinfection by-products given its continuing use of floating covers rather than conventional tanks.
- SGW could consider means to keep analytical instrumentation reagents and standards within their appropriate operating temperature range and seek to minimise variations in that temperature.
- SGW could more clearly label some of its sampling points to help reduce the risk of misunderstanding when samples are collected.
- Where parts and fittings are being stored, SGW could consider providing sufficient space under cover to protect parts and fittings from potential UV degradation
- SGW could consider adding some clear signage on the temporary potable water tanker.
- SGW could consider some formal resilience planning to provide safe water for systems that don't have a backup water supply feed to protect the supply of safe water in the event of untreatable source water contamination or treatment system failure (e.g. Leongatha that is a large system with limited contingency).

South Gippsland Water has actioned or prioritised OFIs for future review, as deemed appropriate. A progress summary is provided in Appendix 4. A progress summary from the previous audit in 2018 is provided in Appendix 5.



Photos: Audit in progress at Wonthaggi Depot and Lance Creek Water Treatment Plant

7. Regulated water

Regulation 16 of the Safe Drinking Water Regulations 2015 requires details of regulated water supplied be included in this annual report. Regulated water is defined as “water that is not intended for drinking but could reasonably be mistaken as drinking water”. South Gippsland Water did not supply any regulated water in the 2020-21 period.

Appendices

Appendix 1: South Gippsland Water's Drinking Water Quality Policy

Drinking Water Quality Policy



"Committed to high-quality drinking water"

South Gippsland Water is committed to providing safe, high-quality drinking water that consistently meets accepted standards, guidelines, regulatory requirements, and customer expectations. To achieve this, in partnerships with stakeholders and relevant agencies, the Corporation will:

- Manage water quality at all points along the delivery chain from source water to consumer;
- Use a risk-based approach to identify and manage potential threats to water quality;
- Continually assess the quality of drinking water through appropriate monitoring programs and effective reporting systems;
- Develop appropriate contingency planning and incident response capability;
- Integrate into our planning the needs and expectations of customers, stakeholders, regulators, and employees;
- Continually improve our management systems by assessing performance against industry best practice, corporate commitments, and stakeholder expectations;
- Participate in appropriate research and development activities to ensure continued understanding of drinking water quality issues and performance;
- Contribute to the debate on setting industry regulations and guidelines, and other standards relevant to public health and the water cycle.

The Corporation will implement and maintain a drinking water quality management system consistent with the NHMRC, NRMCC *Australian Drinking Water Guidelines** to effectively manage risks to drinking water quality.

All managers and employees involved in the supply of drinking water are responsible for understanding, implementing, maintaining, and continuously improving the drinking water quality management system.

This Drinking Water Quality Policy is proudly displayed at South Gippsland Water facilities and is communicated to all persons working for or on the Corporation's behalf during induction or contract proceedings. The Policy is available to the public upon request or via the South Gippsland Water website. Contact details are: –

South Gippsland Water
14-18 Pioneer Street
PO Box 102
Foster, Victoria 3960
(03) 5682 0444

or: sqwater@sqwater.com.au

Appendix 2: Safe Drinking Water Act audit certificate

Risk management plan audit certificate

Safe Drinking Water Regulations 2015 - Regulation 10

Certificate Number: 174

Audit period: 28 April 2018 to 28 August 2020

To: Sarah Salmons, Water Quality Coordinator

South Gippsland Water, PO Box 102, Foster, Vic 3960

Australian Business Number (ABN): 40 349 066 713

I, Dr Daniel Deere, after conducting a risk management plan audit of the water supplied by South Gippsland Water am of the opinion that -

South Gippsland Water has complied with the obligations imposed by section 8(1) of the **Safe Drinking Water Act 2003** during the audit period.

Signature of approved auditor: *DA Deere* Date: 28 Aug 2020

Appendix 3: Amendment to audit certificate



Water Futures Pty Ltd
ABN: 97 109 956 961
66 Merrivale Rd, Pymble, NSW 2073
0409 283 737
dan@waterfutures.net.au

Ms Suzie Sarkis
Manager Water
Department of Health and Human Services
50 Lonsdale Street
Melbourne
Victoria 3000

Dear Ms Sarkis,

Re: incorrect section reference in *Safe Drinking Water Act 2003* risk management plan audit certificate number 174 for South Gippsland Water dated 28 August 2020.

The risk management plan audit certificate, number 174, dated 28 August 2020, submitted by me for South Gippsland Water, referred to an incorrect section of the *Safe Drinking Water Act 2003* (the Act).

Specifically, the audit certificate as issued incorrectly referred to section 8(1) of the Act. The audit certificate should have referred to section 7(1) of the Act.

I hereby request that the certificate be treated as having been amended accordingly.

Please accept my apologies for the inconvenience caused by this error and pass on my thanks to your team for noticing it.

Yours Sincerely,

A handwritten signature in black ink that reads "D Deere".

Dan Deere
Risk Management Plan Auditor

30 October 2020

Appendix 4: Progress summary for 2020 risk management plan audit

| Item | Opportunity for improvement (OFI) | To be implemented | Target completion date | Status as of September 2021 | Comments |
|------|--|-------------------|--------------------------------|-----------------------------|---|
| 1. | Consideration could be given to the possible value of roofing of the (Leongatha) WTP infrastructure to improve ease of maintenance and asset life and reduce slime formation. | To be determined | September 2022 (consideration) | Started | Will be considered for 2023 pricing plan (draft plan is due for submission September 2022). |
| 2. | SGW could consider means to keep analytical instrumentation reagents and standards within their appropriate operating temperature range and seek to minimise variations in that temperature. | Not applicable | Not applicable | Complete | Brick analyser shed at Lance Creek WTP is already installed. OFI is based on a misunderstanding during the audit. Operator was speaking of issues with operating temperatures previous to construction of shed. |
| 3. | SGW may wish to keep track of emerging issues relating to microbial pathogens and disinfection by-products given its continuing use of floating covers rather than conventional tanks. | Yes | On-going | Complete | SGW will keep abreast of emerging issues via on-going review of relevant publications and attendance at seminars, etc. Monitoring of basins is already in place. |
| 4. | SGW could more clearly label some of its sampling points to help reduce the risk of misunderstanding when samples are collected. | Yes | July 2022 | In progress | An audit of existing signage has been conducted. Additional signage will be installed where required |
| 5. | Where parts and fittings are being stored, SGW could consider providing sufficient space under cover to protect parts and fittings from potential UV degradation | Yes | July 2023 | Started | Intended works added to Interim Facilities project. |
| 6. | SGW could consider adding some clear signage on the temporary potable water tanker | Yes | December 2021 | In progress | Design of signage underway |
| 7. | SGW could consider some formal resilience planning to provide safe water for systems that don't have a backup water supply feed to protect the supply of safe water in the event of untreatable source water contamination or treatment system failure (e.g. Leongatha that is a large system with limited contingency). | Yes | July 2023 | In progress | Resilience planning forms part of Urban Water Strategy (UWS) discussions. UWS process will be complete by April 2022. |

Appendix 5: Progress summary for 2018 risk management plan audit

| Item number | Item | Opportunity for improvement (OFI) | Status as of September 2021 | Comments |
|-------------|---|--|-----------------------------|---|
| A1.3.3 | Regularly update the list of relevant agencies. | List of regulatory agencies available but needs update | Complete | List updated regularly (annual to biennial) according to Quality Documents management procedures |
| A2.1.3 | Assemble pertinent information and document key characteristics of the water supply system to be considered. | WQ complaints are in the increase due to discoloration and Taste & odour. | Complete | Lance Ck connection and other improvements have seen a decline in complaints |
| A2.1.4 | Periodically review the water supply system. | Consider event-based (system changes) sampling to understand the systems behaviour. | Complete | Such sampling is conducted routinely and in response to changes. |
| A.2.3.5 | Determine significant risk and document priorities for risk management. | Introduction of VDPs desalinated, Melbourne Cardinia Storage and LC waters blending with associated risks, controls need to be established | Complete | Risks have been documented and controls (e. g. secondary disinfection and pH correction of supplementary Melbourne water) are in place. Connection to Melb grid has been operational since late 2018; No issues with blending waters. |
| A3.1.1 | Identify existing preventive measures from catchment to consumer for each significant hazard or hazardous event and estimate the residual risk. | Source water quality is significantly impacted after rain events. Long term strategies need to be mapped out to reduce DOC in finished waters. Current short-term actions such as Copper Sulphate, PAC dosing and use of Sodium Hexametaphosphate (CALGON) may not meet future “Good Water” customer expectations consistently. | Complete – on-going | Long-term catchment improvement programs are in place and reviewed frequently. This includes on-going revegetation of catchments. Lance Creek Reservoir and Catchment Health study is in progress (due Feb 2022); This will inform improvement strategies. Urban water strategy (due April 2022) will include resilience planning and alternative water supplies options. Alternative water supplies improve adaptability and response to source water quality issues, as has been the case for extensive Lance Ck system (i.e., connection to Melb water grid and extension to Korumburra and PLN systems (2018) has seen better adaptation to source water issues.) Sodium hexametaphosphate no longer in use, Earthtec product is being used instead of Copper sulphate, PAC dosing systems have been improved (for Lance Ck and Foster WTPs). |
| A3.1.2 | Evaluate alternative or additional preventive measures where improvement is required. | Input water quality into water distribution network including Fe, Mn, DBPs & DOC reduction, and network understanding and management is critical moving forward to meet future customer expectations | Complete | Such monitoring is carried out routinely and reviewed frequently. Additional (“Aquadig”) monitoring by contractor (Veolia) has been done to inform flushing and scouring programs. Online manganese monitoring for Lance Ck is due for commissioning by 2022 |

| Item number | Item | Opportunity for improvement (OFI) | Status as of September 2021 | Comments |
|-------------|--|--|-----------------------------|--|
| A3.2.1 | Assess preventive measures from catchment to consumer to identify critical control points. | Formalize the internal audits for compliance with established procedures and documentations. | Complete | On-going auditing of water treatment operations is achieved via WIMS and other checking systems; continual process (rather than single event audit) is adequate as per ADWG. |
| A4.1.2 | Document all procedures and compile into an operation manual. | System integrity checks and control measures are to be reviewed and updated regularly to reflect changes. | Complete | All procedures are subject to frequent review and published on SGW intranet in accordance with SGW quality document management protocols. New procedures are developed when required. |
| A4.3.2 | Establish rapid communication systems to deal with unexpected events. | Catchment risks are high for many of the water systems and impacted by Climate change. EPA, CMA, other information from identified stakeholders requires coordination. | Complete | SGW Emergency Management Plan includes coordination and communication protocols with stake holders. |
| A4.4.1 | Ensure that equipment performs adequately and provides sufficient flexibility and process control. | Calibration frequencies inspected are adequate and processed via the HANSEN asset management system. Maintenance of critical equipment could be improved. e.g. Chemical dosing pumps, injection points, rectifying leaking floating cover roof materials etc. | Complete | Calibration frequencies also managed through WIMS system. Maintenance and renewal programs are in place. These were reviewed and significantly improved in 2019. Works are managed via IPS (formerly known as 'Hansen'). Backlog of work orders has been cleared by dedicated Mechanical-Electrical work group. |
| A4.4.2 | Establish a program for regular inspection and maintenance of all equipment, including monitoring equipment. | Asset Management team are responsible for these tasks and have system in place with limited budget to undertake remedial tasks. | Complete | See A4.4.1 (above) |
| A5.1.1 | Determine the characteristics to be monitored in the distribution system and in water as supplied to consumer. | A well-established DHHS approved monitoring program is in place for compliance sampling. However further studies are required to bring the water quality complaints to acceptable levels. | Complete | See A3.1.1 and A3.1.2. Monitoring for parameters related to aesthetic quality and other characteristics (e.g. nitrification) is conducted routinely. Additional studies are carried out as required. Customer complaints have declined since 2017-18. |
| A5.2.1 | Establish a consumer complaint and response program, including appropriate training of employees. | Evidence suggests adequate program is in place to deal with consumer complaints. | Complete | Proactive programs are in place. E.g. Taste & Odour monitoring, trouble-spot flushing, trials for improved Mn control. Flushing and Scouring could be carried out more frequently, but this can be difficult with limited resources. More frequent monitoring for aesthetic-related parameters has been added to the Monitoring Program. See also A5.1.1 |
| A5.4.2 | Establish rapid communication systems to deal with unexpected events. | Protocols are adequate to deal with unexpected events. Requires updates to keep it current. | Complete | Protocols are reviewed frequently in accordance with SGW quality document review cycle. |

| Item number | Item | Opportunity for improvement (OFI) | Status as of September 2021 | Comments |
|-------------|--|---|-----------------------------|---|
| A6.1.1 | Define communication protocols with the involvement of relevant agencies and prepare a contact list of key people, agencies, and businesses. | WSPs refers to specific references to emergencies and responses. Contact list needs to be updated. | Complete | Contact lists and communication protocols are updated frequently in accordance with SGW quality document review cycle. |
| A6.2.2 | Train employees and regularly test emergency response plans. | Training matrix is in place but requires formalizing by inclusion into position descriptions and follow ups to keep up to date. | Complete | Performance management in new Aurion HRIS (Payroll and HR Information System) includes formalised training requirements. Training requirements will also be managed through new LITMOS (Learning and Development system). Emergency exercises are conducted annually. Regular desktop emergency exercises specific to water treatment and quality are programmed for late 2021. |
| A9.1.1 | Establish programs to increase understanding of the water supply system. | Water network modelling could provide adequate information to manage and minimize WQ related issues within the distribution network. | Complete | Large systems have been modelled, with information being incorporated into plans. |
| A9.1.2 | Use information to improve management of the water supply system. | Improve systems understanding to minimize WQ issues. DOC content, Chlorine residual, Water Quality Complaints. More work is required in this area to reduce the WQ complaints. | Complete | See A3.1.1. Water quality complaints have declined |
| A9.2.1 | Validate processes and procedures to ensure that they are effective at controlling hazards. | External activities from farming have significant impact to the source water quality to many supply systems for SGW. Catchment Knowledge and information feedback is critical. | Complete -on-going | Catchment management programs are in place. HBT assessments are reviewed biennially. Lance Creek Reservoir and Catchment Health study is in progress (due Feb 2022); This will inform improvement strategies. See also A3.1.1 |
| A 9.3.1 | Validate the selection and design of new equipment and infrastructure to ensure continuing reliability. | Understand the review is currently underway to introduce Melbourne's water source into LC water supply system. | Complete | Validation of pumps and automatic control systems based on storage levels was part of commissioning process. Lance Creek connection has been operational since 2018. |
| A11.2.1 | Establish processes for internal and external audits. | Could be improved | Complete | See A3.2.1 |
| A11.2.2 | Document and communicate audit results. | Could be improved | Complete | Results are documented and communicated -email, WaterStream page, MS Teams page and meetings, presentation to ELT, annual report). |

Glossary of acronyms and terms used in report

| | |
|--------------------------|---|
| ADWG | <i>Australian Drinking Water Guidelines</i> 2011; published by the National Health and Medical Research Council |
| Coliforms | A general term for certain types of rod-shaped bacteria that share identifying characteristics. |
| Cyanobacteria | Photosynthetic aquatic bacteria commonly referred to as 'blue-green algae' (though not actually algae). |
| DWMS | Drinking Water Management System |
| 'the Department' | Department of Health and Human Services (State Government of Victoria) |
| <i>E. coli</i> | <i>Escherichia coli</i> : thermotolerant bacteria used as an indicator of faecal contamination |
| HACCP | Hazard Analysis and Critical Control Point |
| < | 'Less than' (mathematical term) |
| > | 'Greater than' (mathematical term) |
| L | Litre: a unit of volume (equal to 1000 cubic centimetres) |
| mg/L | Milligrams per litre: a unit of concentration (one milligram is equal to 0.001 grams) |
| ML | Megalitres: a unit of volume (one megalitre is equal to one million litres) |
| NATA | National Association of Testing Authorities |
| ng/L | Nanograms per Litre: a unit of concentration (one ng is equal to 0.000000001 grams) |
| NHMRC | National Health and Medical Research Council |
| OFI | Acronym for "opportunity for improvement" as noted in audit reports |
| Orgs/100 mL | Organisms/per 100 millilitre of water: a unit of measurement used in microbiology |
| Pathogen | Disease-causing microorganism |
| PAC | Powdered activated carbon |
| PLC | Programmable logic controller: a digital computer used for automation of electromechanical processes |
| Quarter | Time period referring to one quarter of a year, <i>i.e.</i> three months. |
| RMP | Risk Management Plan |
| 'the Act' | <i>Safe Drinking Water Act 2003</i> |
| 'the Regulations' | Safe Drinking Water Regulations 2015 |
| SGW | South Gippsland Water (South Gippsland Region Water Corporation, 'the Corporation') |

Glossary of water treatment agents and processes

| | |
|---|---|
| Aluminium chlorohydrate | Aluminium salt used as a coagulant in water treatment |
| Aluminium sulphate | Aluminium salt used as a coagulant in water treatment |
| Chloramine | A compound of chlorine and ammonia used for disinfection |
| Chlorine | An element used as a disinfectant in water treatment. May be applied in gaseous, elemental form, or via aqueous solution of sodium hypochlorite. |
| Coagulation | A chemical water treatment process that involves neutralisation of charge on particles (impurities) in water. This destabilisation of charge allows for particles to clump together rather than repel each other electrostatically. |
| Dewatering of wastewater | Method of post water treatment water conservation. Removes excess water from sludge so it can be returned to a reservoir and reused. |
| Disinfection | Use of chemical, other agent (e.g. ultraviolet light) or process to kill or inactivate microorganisms which may be harmful to human health. |
| Dissolved air floatation (DAF) clarification | Water treatment process involving use of pressurised air for clarification. Microscopic air bubbles attach to floc and cause floc to float and make a sludge layer. This allows for separation of impurities (as floc) from water. |
| Filtration | Final water treatment process prior to disinfection; clarified water passes through large filters where impurities are entrapped. |
| Flocculation | A physical water treatment process that causes clumps formed through coagulation processes to come together into larger masses known as floc. Formation of floc allows for purification of water via sedimentation and filtration processes. |
| Fluoridation | Addition of fluoride to water for public dental health purposes. |
| Granular medium | Layers of sand, gravel and crushed anthracite that make up a water treatment plant filter. |
| Hydrochloric acid | An acid used to lower the pH of water which enables optimisation of coagulation processes |
| Manganese oxidation | Water treatment process important for minimising dirty/discoloured water complaints. Oxidation of dissolved manganese in raw (source) water causes it to precipitate out of solution as a solid. This in turn allows for the solid oxidised manganese particles to be removed via coagulation, flocculation and filtration processes. |
| Manganese sequestration | Process that may be used to mitigate post treatment manganese oxidation and resulting discolouration of water. Manganese that has not been removed in treatment may oxidise on contact with chlorine disinfectants or air. Sequestration (or chelation) causes manganese to form soluble complexes that do not cause discolouration of water. |
| pH correction (pre/post treatment) | Raw water pH can vary due to environmental factors. Pre pH correction is needed to optimise treatment processes. Post pH treatment may be required to ensure pH is suitable for disinfection, and for distribution to customers in terms of aesthetics and water stability. |
| Polyacrylamide | Chemical polymer which may be used to facilitate flocculation or dewatering processes. Acts by binding particles/floc together. |
| Potassium permanganate | Compound used to oxidise manganese |
| Powdered activated carbon (PAC) | Primarily used to adsorb taste and odour compounds produced by algae from raw water |
| Sedimentation clarification | A physical water treatment process using gravity to remove suspended solids from water |
| Sodium hydroxide | Base used to raise the pH of water and optimise coagulation pH levels. |
| Ultraviolet disinfection | Use of ultraviolet light to kill/inactivate water-borne microorganisms that may be harmful to human health. |

